


PROJECT NARRATIVE

THE PROPOSED REDEVELOPMENT IS AN URBAN, MIXED-USE DEVELOPMENT THAT WILL INCLUDE OFFICE, RESIDENTIAL, HOTEL, ENTERTAINMENT, RETAIL, ACADEMIC, AND RESTAURANT USES TO BE LOCATED WITHIN A NEW NETWORK OF STREETS AND OPEN SPACES. THE PROJECT WILL PROVIDE A NEW STREET NETWORK INCLUDING ENHANCED SIDEWALK AND STREETScape, BICYCLE AND PEDESTRIAN INFRASTRUCTURE, AND OPEN SPACES THROUGHOUT THE PROJECT. THE REDEVELOPMENT WILL ALSO INCLUDE A WATER MANAGEMENT MASTER PLAN, ENVIRONMENTAL SUSTAINABILITY MASTER PLAN, AND A CONCEPTUAL DESIGN PLAN, TO BE SUBMITTED UNDER SEPARATE COVER. THIS DSP IS FOR THE DEVELOPMENT OF THE NEW STREET NETWORK.

PRELIMINARY DEVELOPMENT SITE PLAN
NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN

ALEXANDRIA, VIRGINIA

VICINITY MAP
SCALE 1"= 2000'



PROFESSIONAL SEAL AND SIGNATURE	DATE	REVISION
	12-17-2020	FIRST SUBMISSION
	03-17-2020	COMPLETENESS COMMENTS
	04-06-2020	COMPLETENESS RESUBMISSION

OWNER/APPLICANT
CPYR THEATER LLC
277 Park Avenue
36th Floor
New York, NY 10172
(212) 648-2129

DEVELOPMENT MANAGER
JBG SMITH
4747 Bethesda Avenue
Suite 200
Bethesda, MD 20814
(240) 333-3600

CIVIL ENGINEER
christopher consultants,ltd.
9900 Main Street
Fourth Floor
Fairfax, Virginia 22031
(703) 273-6820

MASTER PLANNER
Elkus Manfredi Architects
25 Drydock Avenue
Boston, Massachusetts 02210
(617) 426-1300

TRAFFIC ENGINEER
Kimley-Horn & Associates
11400 Commerce Park Drive
Suite 400
Reston, Virginia 22102
(703) 674-1300

ATTORNEY
Walsh, Colucci, Lubeley & Walsh
Courthouse Plaza
2200 Clarendon Boulevard
Suite 1300
Arlington, VA 22201-3359
(703) 528-4700

PUMP STATION ENGINEER
Gannett Fleming, Inc.
7133 Rutherford Road
Suite 300
Baltimore, Maryland 21244
(410) 907-2684

LIST OF EXISTING APPROVALS:

- MASTER PLAN AMENDMENT #2019-00008
- REZONING #2009-0001
- CDD CONCEPTUAL DESIGN PLAN #2009-0001
- TRANSPORTATION MANAGEMENT PLAN SUP #2009-0061

LIST OF REQUESTED SITE PLANS AND AMENDMENTS:

- CDD CONCEPTUAL DESIGN PLAN AMENDMENT
- DSUP WITH PRELIMINARY SITE PLAN FOR PUMP STATION
- DSP WITH PRELIMINARY INFRASTRUCTURE SITE PLAN

SHEET INDEX

C100	COVER SHEET
C101	NOTES & TABULATIONS
C102	CONTEXTUAL PLAN
C102.1-C102.2	PUBLIC VS. PRIVATE ROAD EXHIBIT
C103	CONTAMINATED SOILS EXHIBIT
C104	PHASING EXHIBIT
C200	OVERALL EXISTING CONDITIONS & KEY PLAN
C201-C203	EXISTING CONDITIONS PLAN
C300-C302	SITE PLAN
C400-C402	UTILITY PLAN
C500-C502	GRADING PLAN
C600	PRE VS. POST DEVELOPMENT IMPERVIOUS
C601	SWM COMPUTATIONS AND NARRATIVES
C602	BMP DETAILS AND NARRATIVES
C603 - C605	SWM-BMP PLAN
C606-C607	BMP COMPUTATIONS
C700	SANITARY SEWER PLAN
C701	ONSITE SANITARY SEWER COMPUTATIONS
C702	OFFSITE SANITARY SEWER COMPUTATIONS PHASE I
C703	EXISTING 30" SANITARY TRUNK SEWER EXHIBIT
C800 - C804	SIGHT DISTANCE PLAN & PROFILE
C900-C904	TURNING MOVEMENTS
A1	PHASE I OPEN SPACE PLAN
A2	PHASE I INTERIM TRANSPORTATION PLAN
P-1	PUMP STATION GRADE LEVEL PLAN
P-2	PUMP STATION LOWER LEVEL PLAN
P-3	PUMP STATION SECTION
P-4	PUMP STATION SECTION
E-1	POWER ONE LINE DIAGRAM

APPROVED		
DEVELOPMENT SITE PLAN NO. _____		
DEPARTMENT OF PLANNING & ZONING		
DIRECTOR		DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES		
SITE PLAN No. _____		
DIRECTOR		DATE
CHAIRMAN, PLANNING COMMISSION		
DATE RECORDED		DATE
INSTRUMENT NO.	DEED BOOK NO.	PAGE NO.

ZONING TABULATIONS

SITE ADDRESSES & TAX MAP NUMBERS:	016.02-01-03 (3601 POTOMAC AVENUE)
EXISTING ZONE:	COORDINATED DEVELOPMENT DISTRICT #19 (CDD)
PROPOSED ZONE:	COORDINATED DEVELOPMENT DISTRICT #19 (CDD)
SMALL AREA PLAN DISTRICT:	NORTH POTOMAC YARD
EXISTING SITE AREA:	817,853 S.F. OR 18.77 AC.
EXISTING USE:	THEATER
PROPOSED USE:	OFFICE, RESIDENTIAL, HOTEL, ENTERTAINMENT, RETAIL, ACADEMIC AND RESTAURANT
PROPOSED SITE AREA:	818,057 S.F. OR 18.78 AC.
APPROXIMATE TOTAL AREA DISTURBED:	1,001,269 S.F. OR 22.99 AC.
EX. IMPERVIOUS AREA:	294,466 S.F. OR 6.76 AC.
PR. IMPERVIOUS AREA:	169,448 S.F. OR 3.89 AC.
EXISTING AVG. DAILY TRIPS:	1,335 TRIPS
PROPOSED AVG. DAILY TRIPS:	N/A
OPEN SPACE REQUIRED: (GROUND LEVEL)	15% GROUND LEVEL 2.81 AC. OR 122,678 SF
OPEN SPACE PROVIDED: (GROUND LEVEL)	6.73 AC. OR 293,100 SF (REFER TO SHEET A1 FOR LOCATION OF OPEN SPACE)

GENERAL NOTES

- THE BOUNDARY SURVEY WAS PREPARED BY christopher consultants.
- THE TOPOGRAPHIC SURVEY WAS OBTAINED FROM AN AERIAL SURVEY AND SUPPLEMENTED WITH FIELD TOPO DATED 10-11-19.
- THE SITE IS CURRENTLY DEVELOPED AS THE POTOMAC YARD CENTER. THERE ARE NO NATURAL FEATURES ON THE SITE THAT NEED TO BE PRESERVED OR PROTECTED. THERE IS A RESOURCE PROTECTION AREA (RPA) BUFFER ADJACENT TO THE OFFSITE FOUR MILE RUN. AREAS OF THE RPA LINE ON THIS SITE ARE NOT IN THEIR NATURAL STATE. MODIFICATIONS TO THIS AREA WILL BE IN ACCORDANCE WITH CURRENT CITY OF ALEXANDRIA REQUIREMENTS FOR REDEVELOPMENT WITHIN THE RPA.
- ANY POTENTIAL NEGATIVE IMPACT ON ADJOINING PROPERTIES BY THIS PROPOSED PROJECT WILL BE MITIGATED BY PROVIDING ADEQUATE PUBLIC INFRASTRUCTURE, MINIMIZING TRAFFIC IMPACTS AND PRESERVING THE RESOURCE PROTECTION AREA.
- TO THE BEST OF OUR KNOWLEDGE THERE ARE NO MARINE CLAYS ON SITE.
- TO THE BEST OF OUR KNOWLEDGE CONTAMINATED SOIL MAY INCLUDE ARSENIC WITH ZONES OF ELEVATED PETROLEUM COMPOUNDS AND/OR LEAD. SEE SHEET C103 FOR CONTAMINATED SOILS EXHIBIT.
- FINAL STREET LIGHT FIXTURES TO BE DETERMINED WITH THE FINAL INFRASTRUCTURE PLAN.

UTILITY CONTACTS:


HASHINGTON GAS	VERIZON
MR. PAT ESTRADA-PALMA 6801 INDUSTRIAL ROAD SPRINGFIELD, VA 22151 (703) 750-4289	MR. STEVE H PURYEAR, SUPERVISOR-ENGINEERING 2980 FAIRVIEW PARK DRIVE, 6TH FLOOR FALLS CHURCH, VA 22042 (703) 204-5072
DOMINION VIRGINIA POWER	VIRGINIA AMERICAN WATER COMPANY
MR. KEN HOLMES 907 WEST GLEBE ROAD. ALEXANDRIA, VA 22305 (703) 838-2478	STEVEN CHEN 2225 DUKE STREET ALEXANDRIA, VA 22314 (703) 706-3863
COMCAST CABLE	CITY OF ALEXANDRIA DEPARTMENT OF TRANSPORTATION & ENVIRONMENTAL SERVICES
MR. GUSTAVO CATELLON 2707 WILSON BLVD. ARLINGTON, VA 22201 (703) 926-0534	301 KING STREET, ROOM 1100 ALEXANDRIA, VA 22314 (703) 746-4025

ARCHAEOLOGY NOTES

- THE FINAL SITE PLAN, GRADING PLAN, OR ANY OTHER PERMITS INVOLVING GROUND-DISTURBING ACTIVITIES (SUCH AS CORING, GRADING, FILLING, VEGETATION REMOVAL, UNDERGROUNDING UTILITIES, PILE DRIVING, LANDSCAPING AND OTHER EXCAVATIONS AS DEFINED IN SECTION 2-151 OF THE ZONING ORDINANCE) SHALL NOT BE RELEASED UNTIL THE CITY ARCHAEOLOGIST CONFIRMS THAT ALL ARCHAEOLOGICAL FIELD WORK HAS BEEN COMPLETED OR THAT AN APPROVED RESOURCE MANAGEMENT PLAN IS IN PLACE TO RECOVER SIGNIFICANT RESOURCES IN CONCERT WITH CONSTRUCTION ACTIVITIES. TO CONFIRM, CALL ALEXANDRIA ARCHAEOLOGY AT (703) 746-4399.
- CALL ALEXANDRIA ARCHAEOLOGY (703-746-4399) TWO WEEKS BEFORE THE STARTING DATE OF ANY GROUND DISTURBANCE SO THAT AN INSPECTION OR MONITORING SCHEDULE FOR THE CITY ARCHAEOLOGISTS CAN BE ARRANGED.
- THE APPLICANT / DEVELOPER SHALL CALL ALEXANDRIA ARCHAEOLOGY IMMEDIATELY (703-746-4399) IF ANY BURIED STRUCTURAL REMAINS (WALL FOUNDATIONS, WELLS, PRIVIES, CISTERNS, ETC.) OR CONCENTRATIONS OF ARTIFACTS ARE DISCOVERED DURING DEVELOPMENT. WORK MUST CEASE IN THE AREA OF THE DISCOVERY UNTIL A CITY ARCHAEOLOGIST COMES TO THE SITE AND RECORDS THE FINDS.
- THE APPLICANT / DEVELOPER SHALL NOT ALLOW ANY METAL DETECTION AND/OR ARTIFACT COLLECTION TO BE CONDUCTED ON THE PROPERTY, UNLESS AUTHORIZED BY ALEXANDRIA ARCHEOLOGY. FAILURE TO COMPLY SHALL RESULT IN PROJECT DELAYS.

Refractive (R54) Specification Sheet

Project Name:	Location:	MFG: Philips Hadco
Fixture Type:	Catalog No.:	Qty:



Ordering Guide
Example: R54 A A B A 1 A D B D 70H E

Product Code	R54	Refractive
Filter/Pod	A	Octagonal Style
B	Round fluted w/ scalloped petals	
C	Fluted tapered hourglass	
D	Smooth tapered hourglass	
E	Tapered fluted w/ scalloped petals	
F	Short round fluted	
G	Tall round fluted	
H	Round contemporary	
J	Tapered Fluted w/ round stepped filter	
L	Round fluted long	
T	Decorative Leaf w/ scalloped petals	
Roof	A	Victorian
B	Acorn	
C	Tall	
D	Short	
G	Adams	
Cage / Band	A	Cage for Wide Body Globe
F	Band for Wide Body Globe	*1
E	Cage for Wide Body Globe	*1
J	Cage for Wide Body Globe	*1
I	Cage for Wide Body Globe	*1
N	None	
Finial	A	A Finial
B	B Finial	
C	C Finial	*2
D	D Finial	*2
E	E Finial	*2
F	F Finial	
G	G Finial	
H	H Finial	
N	None	
Fasteners	I	Hex Head
A	Allen Head	
Finish	A	Black
B	White	
G	Verde	
H	Bronze	
J	Green	
Reflector	D	Small Top Reflector
G	Small Top Reflector w/House-side shield	
H	House Side Shield	
I	Internal Lower Assembly	
N	Full Top Reflector	*3
Photo Control	B	Button Eye Photo Control
N	None	
Socket	N	Medium
A	Moog	*5
R	Induction	*5
Wattage	70H	70W MH
100H	100W MH	
120H	150W PMH	
150H	150W PMH	
320H	320W PMH	
50S	50W HPS	
70S	70W HPS	
70DS	100W HPS	
100S	150W HPS	

ISO 9001:2008 Registered Page 1 of 4
PHILIPS HADCO
Note: Philips reserves the right to modify the above details to reflect changes in the cost of materials and/or production and/or design without prior notice.
100 Craftway Drive, Littlestown, PA 17340 | P: +1-717-359-7131 F: +1-717-359-9289 | http://www.hadco.com | Copyright 2011 Philips HW1

Refractive (R54) Specification Sheet

Project Name:	Location:	MFG: Philips Hadco
Fixture Type:	Catalog No.:	Qty:

Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 9" and width is 9". Finish is polyester thermostat powdercoat.

- H: Round contemporary filter is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal twist-lock photo eye receptacle (available for 200W MH max or 150W HPS max) or optional internal button eye photocell. Easy access to photocell through tool-less door on pod. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 10" and width is 10". Finish is polyester thermostat powdercoat.
- J: Tapered fluted filter with round stepped filter is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal twist-lock photo eye receptacle or button eye photocell. Tool-less access to photo eye through the door on the pod. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 12" and width is 12". Finish is polyester thermostat powdercoat.
- L: Round fluted long filter is constructed of 356 HM High-Strength, Low-Copper cast aluminum with a side-hinged door providing entry into the filter assembly for easy access to the electrical components. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal twist-lock photo eye receptacle or button eye photocell. Easy access to photo eye through the door on the pod. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is attached using four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). Pod height is 12-1/2" and width is 10-3/4". Finish is polyester thermostat powdercoat.
- T: Decorative Leaf filter with scalloped petals is constructed of 356 HM High-Strength, Low-Copper cast aluminum with side-hinged door providing 180° entry into the filter assembly for easy access to the electrical components. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal twist-lock photo eye receptacle or optional button eye photocell. Easy access to photo eye through the door on the pod. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 15-1/4" and width is 11-1/2". Finish is polyester thermostat powdercoat.

ROOF:
A: Victorian style roof is clear injection molded U.V. stabilized acrylic with 99 horizontal prisms for a soft, even glow. 13" height and 16-1/2" width. The roof and bottom globe sections are secured in a slip-fit, 1/2" overlap design and use four #10-24 stainless steel pan head screws with four aluminum nuts providing a mechanical lock and enabling easy future replacement of either the roof or bottom globe section if required.
B: Acorn style roof is clear injection molded U.V. stabilized acrylic with 74 horizontal prisms for a soft, even glow. 9-1/2" height and 16-3/4" width. The roof and bottom globe sections are secured in a slip-fit, 1/2" overlap design and use four #10-24 stainless steel pan head screws with four aluminum nuts providing a mechanical lock and enabling easy future replacement of either the roof or bottom globe section if required.
C: Roof is 0.060" thick spun aluminum. 12" height and 17" width. The roof and bottom globe sections are secured in a slip-fit, 1/2" overlap design and use four #10-24 stainless steel pan head screws with four aluminum nuts providing a mechanical lock and enabling easy future replacement of either the roof or bottom globe section if required. Finish is polyester thermostat powdercoat.

D: Roof is 0.060" thick spun aluminum. 8-1/2" height and 16-1/2" width. The roof and bottom globe sections are secured in a slip-fit, 1/2" overlap design and use four #10-24 stainless steel pan head screws with four aluminum nuts providing a mechanical lock and enabling easy future replacement of either the roof or bottom globe section if required. Finish is polyester thermostat powdercoat.

G: Roof is 0.080" thick spun aluminum. 10-1/2" height and 16-3/4" width. The roof and bottom globe sections are secured in a slip-fit, 1/2" overlap design and use four #10-24 stainless steel pan head screws with four aluminum nuts providing a mechanical lock and enabling easy future replacement of either the roof or bottom globe section if required. Finish is polyester thermostat powdercoat.

CAGES AND BANDS:
B: Cage for Wide body globes (16-1/2" dia.) is constructed of die-cast 360 aluminum alloy. Cage has 4 legs each with square decorative flower block. Solid rectangular band around top of cage. Height of cage is 15" and width of cage is 20". Finish is polyester thermostat powdercoat. (NOTE: Cannot be used with "A" Pod.)
E: Band for Wide body globes (16-1/2" dia.) is architectural slotted aluminum. Supported at 4 points by cast aluminum square flower blocks. Finish is polyester thermostat powdercoat.
F: Band for Wide body globes (16-1/2" dia.) is architectural slotted aluminum supported at 4 points by cast aluminum round flower blocks. Finish is polyester thermostat powdercoat.

G: Cage for Wide body globes (16-1/2" dia.) is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Arched, decorative legs are welded to form a one-piece unit. Height of cage is 12" and width of cage is 16-1/2". Finish is polyester thermostat powdercoat. (NOTE: Cannot be used with "A" Pod.)
I: Cage for Wide body globes (16-1/2" dia.) is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Cage has 2 curved legs. Solid fluted band around top of cage. Height of cage is 14-1/2" and width of cage is 19-3/4". Finish is polyester thermostat powdercoat. (NOTE: Cannot be used with "A" Pod.)
J: Cage for Wide body globes (16-1/2" dia.) is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Cage has 4 curved legs. Solid fluted band around top of cage. Height of cage is 14-1/2" and width of cage is 19-3/4". Finish is polyester thermostat powdercoat. (NOTE: Cannot be used with "A" Pod.)

FINIALS:
All finials are cast aluminum mounted with 1/4-20 stainless steel threaded studs. Standard finial finish will match fixture finish as specified. Finish is thermostat powdercoat. (NOTE: C, D, and E finials are not available with "B" Roof.)

ISO 9001:2008 Registered Page 4 of 4
PHILIPS HADCO
Note: Philips reserves the right to modify the above details to reflect changes in the cost of materials and/or production and/or design without prior notice.
100 Craftway Drive, Littlestown, PA 17340 | P: +1-717-359-7131 F: +1-717-359-9289 | http://www.hadco.com | Copyright 2011 Philips HW1

Refractive (R54) Specification Sheet

Project Name:	Location:	MFG: Philips Hadco
Fixture Type:	Catalog No.:	Qty:

	200S	200W HPS	*7
	250S	250W HPS	*7
	310S	310W HPS	*7
	50S	50W Induction	*6
	80S	80W Induction	*6
	160S	160W Induction	*6
Voltage	E	120V	
	F	208V	
	G	240V	
	H	277V	
	K	347V	*8

*1 Not available with (A) pod.
*2 Cannot be used with (B) roof.
*3 Cannot be used with Induction Lamping.
*4 Twislock photocell receptacle (R) is available in (A), (G), (H), and (J) pod up to 150W HPS and 200W MH. Pods (S), (L), and (T) available in all wattages. Not available in other pods.
*5 Medium base (D) socket available for 70W-175W MH, 50W-150W HPS. Mogul base (C) socket available for 150W-320W MH, 50W-310W HPS.
*6 Consult factory if ordering Induction socket (R) and wattages.
*7 Available in (A), (B), (E), (G), (H), (L), and (T) pods.
*8 347V (K) not available for (O.S.).

Specifications

HOUSING:
OPTIONAL PODS:
A: Octagonal style filter is constructed of die-cast 360 aluminum alloy with bottom-hinged door providing 135° entry into the filter assembly for easy access to the electrical components. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal twist-lock photo eye receptacle (available for 200W MH max or 150W HPS max) or optional button eye photocell. Easy access to photo eye through the door on the pod. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 15-3/4" and width is 10-1/4". Finish is polyester thermostat powdercoat.
B: Round filter with scalloped petals is constructed of die-cast 360 aluminum alloy with side-hinged door providing 180° entry into the filter assembly for easy access to the electrical components. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal button eye photocell. Easy access to photo eye through the door on the pod. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 9" and width is 9-3/4". Finish is polyester thermostat powdercoat.
C: Fluted tapered hourglass filter is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Accepts standard HADCO Twislock ballast assemblies up to 150W HPS or 200W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal button eye photocell. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 8" and width is 8-3/4". Finish is polyester thermostat powdercoat.
D: Smooth tapered hourglass filter is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Accepts standard HADCO Twislock ballast assemblies up to 150W HPS or 200W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal button eye photocell. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 8" and width is 8-3/4". Finish is polyester thermostat powdercoat.
E: Tapered fluted filter with scalloped flower petals is constructed of 356 HM High-Strength, Low-Copper cast aluminum. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal button eye photocell. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 8" and width is 8-3/4". Finish is polyester thermostat powdercoat.
F: Short Round fluted filter is constructed of die-cast 360 aluminum alloy. Accepts standard HADCO Twislock ballast assemblies up to 150W HPS or 200W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal button eye photocell. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified) for mounting to 3" O.D. post tenon. Globe holder has an internal water trap to prevent water from entering ballast compartment. Globe is held by utilizing four 5/16-18 black cadmium stainless steel fasteners (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 7-1/2" and width is 9-1/4". Finish is polyester thermostat powdercoat.
G: Tall Round fluted filter is constructed of die-cast 360 aluminum alloy with removable door providing entry into the filter assembly for easy access to the electrical components. Accepts standard HADCO Twislock ballast assemblies up to 310W HPS or 320W MH. Wiring block to accept three #8 solid or stranded wires. Optional internal button eye photocell. Easy access to photo eye through the door on the pod. Heavy cast aluminum post filter utilizes four 5/16-18 black cadmium stainless steel set screws (Hex head or Allen head as specified). All hardware to be stainless steel and captive. Pod height is 12-1/2" and width is 10-3/4". Finish is polyester thermostat powdercoat.

ISO 9001:2008 Registered Page 2 of 4
PHILIPS HADCO
Note: Philips reserves the right to modify the above details to reflect changes in the cost of materials and/or production and/or design without prior notice.
100 Craftway Drive, Littlestown, PA 17340 | P: +1-717-359-7131 F: +1-717-359-9289 | http://www.hadco.com | Copyright 2011 Philips HW1

Refractive (R54) Specification Sheet

Project Name:	Location:	MFG: Philips Hadco
Fixture Type:	Catalog No.:	Qty:

FASTENERS:
Used to secure post filter to post tenon and globe to globe holder.
1: Hex Head Bolts: Black cadmium stainless steel.
2: Allen Head Bolts: Black cadmium stainless steel.

FINISH:
Thermostat polyester powdercoat is electrostatically applied after a five-stage conversion cleaning process and bonded by heat fusion thermostating. Laboratory tested for superior weatherability and fade resistance in accordance with ASTM B117 specifications. For larger projects where a custom color is required, contact the factory for more information.

OPTICAL ASSEMBLY:
GLOBE AND OPTICAL ASSEMBLY:
Type V Wide body globe is constructed of clear injection-molded U.V. stabilized acrylic. A two-piece (Globe and Roof) slip-fit, 1/2" overlap, design utilizes nuts and stainless steel fasteners, which eliminates a "butt-glue" seam appearance. The optical section of the globe has a neck opening of 7-3/8" and an outside neck diameter of 8". Globe (less the roof) has a 12-7/8" height and 16-3/4" width at the top with 96 horizontal prisms and 360 highly polished vertical prisms.

REFLECTORS AVAILABLE:
D: Small Top Reflector: Top reflector is 0.04" thick #3003 aluminum alloy. Diameter is 6-1/2" and Height is 3". Precision formed, highly polished specular aluminum finish. Mounted horizontally to control uplight. Tool-less attachment of reflector bracket to socket with stainless steel spring clip.

F: Small Top Reflector with House Side Shield: Top reflector is 0.04" thick #3003 aluminum alloy. Diameter is 6-1/2" and Height is 3". Side reflector is 0.02" thick. Precision formed, highly polished specular aluminum finish. Top is mounted horizontally to control uplight while house-side shield is mounted vertically to control backlight. Tool-less attachment of reflector bracket to socket with stainless steel spring clip. Rotatable 360 degrees.

G: Top Reflector with House Side Shield: Top reflector is 0.04" thick hydroformed aluminum with a clear anodized highly specular finish. Diameter is 14-1/4" and Height is 6-1/4". Reflector rests on top internal prism wall of the bottom globe section to control uplight. House-side reflector is 0.02" thick aluminum alloy. Precision formed highly polished specular aluminum finish. Mounted vertically to control backlight. Tool-less attachment of reflector bracket to socket with stainless steel spring clip. Rotatable 360 degrees.

H: House-Side Shield: House-side reflector is 0.02" thick aluminum alloy. Precision formed highly polished specular aluminum finish. Mounted vertically to control backlight. Tool-less attachment of reflector bracket to socket with stainless steel spring clip. Rotatable 360 degrees.

L: Internal Lower Assembly: Optically designed 0.06" thick highly polished, specular Alzadco aluminum, internal louvers. Tool-less attachment of reflector bracket to socket with stainless steel spring clip. Rotatable 360 degrees. (NOTE: cannot be used with Induction Lamping.)

T: Top Reflector: Top reflector is 0.04" thick hydroformed aluminum with a clear anodized highly specular finish. Diameter is 14-1/4" and Height is 6-1/4". Reflector rests on top internal prism wall of the bottom globe section to control uplight.

ELECTRICAL ASSEMBLY:
Twislock Ballast Assembly with Quick Disconnects for easy maintenance. Ballasts are HPS core and coil. 4kv rated mogul base porcelain socket. Nickel-plated screw shell with center contact. 4kv rated porcelain mini-can base. Nickel-plated screw shell with center contact. Consult factory if ordering Induction Lamping and Power Coupler.

BALLAST:
All HID ballasts are core and coil and regulated with power factors better than 90% (HPF). Ballasts provide +/- 5% lamp power regulation with +/- 10% input voltage regulation. Ballasts are factory pre-wired and tested. Metal halide ballasts are capable of starting at -20° F or -30° C and HPS at -40° F or -40° C. NOTE: All ballasts are EISA / Title 20 / Title 24 compliant where applicable.

CERTIFICATIONS:
ETL Listed to U.S. safety standards for wet locations. cETL listed to Canadian safety standards for wet locations. Manufactured to ISO 9001:2008 Standards.

WARRANTY:
Three-year limited warranty.

Max. EPA:
2.20 sq. Ft. (Varies depending on options selected)

Max. Weight:
50 lbs.

IESNA Classifications:
See Cutoff with C and D roof and/or G or T roof

ISO 9001:2008 Registered Page 4 of 4
PHILIPS HADCO
Note: Philips reserves the right to modify the above details to reflect changes in the cost of materials and/or production and/or design without prior notice.
100 Craftway Drive, Littlestown, PA 17340 | P: +1-717-359-7131 F: +1-717-359-9289 | http://www.hadco.com | Copyright 2011 Philips HW1

LEGEND

---	260	:EX. INDEX CONTOUR MAJOR
---	258	:EX. INT. CONTOUR MINOR
---	260	:PROPOSED INDEX CONTOUR MAJOR
---	258	:PROPOSED INT. CONTOUR MINOR
---		:EX. PROPERTY LINE
---		:PROP. RIGHT-OF-WAY
---		:PROP. ROAD CENTERLINE
---		:PROP. CURB
---		:PROP. EDGE OF PAVEMENT
---		:EX. ADJACENT PROPERTY LINE
---		:EX. TREE LINE
---		:EX. CURB & GUTTER
---		:EX. FENCE
---		:EX. LIGHT
---		:EX. ELECTRIC
---		:EX. WATERLINE
---		:EX. STORM SEWER
---		:EX. TELECOM
---		:EX. SANITARY FORCE MAIN
---		:EX. SANITARY SEWER
---		:EX. SANITARY MANHOLE
---		:PROP. PARKING SPACES
---		:PROPOSED STORM SEWER
---		:PROPOSED SANITARY SEWER
---		:PROPOSED WATER LINE
---		:PROPOSED GAS LINE
---		:PROPOSED ELECTRIC LINE
---		:PROPOSED FIRE HYDRANT
---		:PROPOSED STREET LIGHT
---		:ACCESSIBLE CURB RAMP
---		:PROPOSED STORM STRUCTURE NUMBER
---		:PROPOSED STORM LABEL
---		:PROPOSED STORM MANHOLE
---		:PROPOSED SANITARY SEWER STRUCTURE NUMBER
---		:PROPOSED SANITARY SEWER LABEL
---		:PROPOSED SANITARY SEWER MANHOLE
---		:TO BE VACATED
---		:TO BE REMOVED
---		:EX. TREE
---		1234 = ID NUMBER
---		11.22 = ELEVATION

NOTE

AN ALTERNATE LIGHT FIXTURE WILL BE DETERMINED AT FINAL SITE PLAN.

APPROVED
DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES

SITE PLAN No. _____

DIRECTOR DATE

CHAIRMAN, PLANNING COMMISSION DATE

DATE RECORDED

INSTRUMENT NO. DEED BOOK NO. PAGE NO.

christopher consultants
p 804-389-9903
2920 w. broad st.
suite 222
richmond, va 23230
engineering surveying land planning

COMMONWEALTH OF VIRGINIA
JOHN L. HELMS

D

C

B

A

2

63

4

5

6

SEE SHEET C201/300/400/500/601

SEE SHEET C202/301/401/501/602

SEE SHEET C203/302/402/502/603

1897	DT	SYCAMORE	28	12	EAST SIDE OF POTOMAC AVE	TBR
1899	DT	SYCAMORE	24	10	EAST SIDE OF POTOMAC AVE	TBR
1907	DT	SYCAMORE	36	18	EAST SIDE OF POTOMAC AVE	TBR
1909	DT	SYCAMORE	24	10	EAST SIDE OF POTOMAC AVE	TBR
1917	DT	SYCAMORE	32	12	EAST SIDE OF POTOMAC AVE	TBR
3750	DT	SYCAMORE	18	9	EAST SIDE OF POTOMAC AVE	TBR
7952	DT	SYCAMORE	10	6	WEST SIDE OF POTOMAC AVE	TBS
7948	CT	SYCAMORE	10	6	WEST SIDE OF POTOMAC AVE	TBS
7945	CT	SYCAMORE	10	6	WEST SIDE OF POTOMAC AVE	TBS
7001	DT	SYCAMORE	24	10	ALONG EASTERN PROPERTY LINE	TBS
7002	CT	SYCAMORE	30	12	ALONG EASTERN PROPERTY LINE	TBS
7003	CT	SYCAMORE	26	10	ALONG EASTERN PROPERTY LINE	TBS
7004	CT	SYCAMORE	30	14	ALONG EASTERN PROPERTY LINE	TBS
7005	DT	SYCAMORE	34	12	ALONG EASTERN PROPERTY LINE	TBS
7006	DT	SYCAMORE	30	11	ALONG EASTERN PROPERTY LINE	TBS
7007	DT	SYCAMORE	38	13	ALONG EASTERN PROPERTY LINE	TBS
7008	DT	SYCAMORE	16	6	ALONG EASTERN PROPERTY LINE	TBS
7009	CT	SYCAMORE	30	15	NORTH OF EX. NORTHERN POND	TBR
7010	CT	SYCAMORE	28	15	NORTH OF EX. NORTHERN POND	TBR
7011	CT	SYCAMORE	32	16	NORTH OF EX. NORTHERN POND	TBR
6426	CT	CEDAR	20	10	ALONG EASTERN PROPERTY LINE	TBR
6427	DT	SYCAMORE	32	10	ALONG EASTERN PROPERTY LINE	TBR
6428	DT	LOCUST	28	10	ALONG EASTERN PROPERTY LINE	TBS
6429	DT	LOCUST	32	8	ALONG EASTERN PROPERTY LINE	TBS
2430	CT	CEDAR	16	8	ALONG EASTERN PROPERTY LINE	TBR
6431	CT	CEDAR	20	8	ALONG EASTERN PROPERTY LINE	TBR
6432	DT	POPLAR	16	8	ALONG EASTERN PROPERTY LINE	TBR
6433	DT	MAPLE	16	6	ALONG EASTERN PROPERTY LINE	TBR
6434	CT	CEDAR	20	10	ALONG EASTERN PROPERTY LINE	TBR
6435	DT	SYCAMORE	32	12	ALONG EASTERN PROPERTY LINE	TBR
6436	CT	CEDAR	18	8	ALONG EASTERN PROPERTY LINE	TBR
6437	CT	CEDAR	18	8	ALONG EASTERN PROPERTY LINE	TBR
6438	CT	CEDAR	16	6	ALONG EASTERN PROPERTY LINE	TBR
6439	CT	CEDAR	16	6	ALONG EASTERN PROPERTY LINE	TBR
6440	CT	CEDAR	16	8	ALONG EASTERN PROPERTY LINE	TBR


6441	DT	SYCAMORE	32	10	ALONG EASTERN PROPERTY LINE	TBR
6442	DT	SYCAMORE	28	10	ALONG EASTERN PROPERTY LINE	TBR
6443	DT	LOCUST	28	12	ALONG EASTERN PROPERTY LINE	TBS
6444	DT	LOCUST	32	12	ALONG EASTERN PROPERTY LINE	TBS
6445	DT	LOCUST	40	16	ALONG EASTERN PROPERTY LINE	TBS
6446	DT	POPLAR	18	9	ALONG EASTERN PROPERTY LINE	TBR
6447	CT	PINE	16	8	ALONG EASTERN PROPERTY LINE	TBR
6448	CT	PINE	16	8	ALONG EASTERN PROPERTY LINE	TBR
6449	DT	MAPLE	12	6	ALONG EASTERN PROPERTY LINE	TBR
6450	DT	SYCAMORE	16	6	ALONG EASTERN PROPERTY LINE	TBR
6451	DT	SYCAMORE	16	6	ALONG EASTERN PROPERTY LINE	TBR
6452	DT	MAPLE	17	8	ALONG EASTERN PROPERTY LINE	TBR
6453	CT	PINE	18	6	ALONG EASTERN PROPERTY LINE	TBR
6454	CT	PINE	19	6	ALONG EASTERN PROPERTY LINE	TBR
6455	CT	CEDAR	20	8	ALONG EASTERN PROPERTY LINE	TBR
6456	CT	CEDAR	21	8	ALONG EASTERN PROPERTY LINE	TBR
6457	CT	CEDAR	22	8	ALONG EASTERN PROPERTY LINE	TBR
6458	CT	CEDAR	23	8	ALONG EASTERN PROPERTY LINE	TBR
6459	DT	LOCUST	28	12	ALONG EASTERN PROPERTY LINE	TBS
6460	DT	LOCUST	44	18	ALONG EASTERN PROPERTY LINE	TBS
6461	DT	SYCAMORE	40	14	ALONG EASTERN PROPERTY LINE	TBR
6462	CT	CEDAR	16	8	ALONG EASTERN PROPERTY LINE	TBS
6463	CT	CEDAR	16	8	ALONG EASTERN PROPERTY LINE	TBS
6464	CT	CEDAR	16	8	ALONG EASTERN PROPERTY LINE	TBS
6465	CT	CEDAR	14	7	ALONG EASTERN PROPERTY LINE	TBS
6466	CT	CEDAR	15	7	ALONG EASTERN PROPERTY LINE	TBS
6467	CT	CEDAR	16	7	ALONG EASTERN PROPERTY LINE	TBS
6468	CT	CEDAR	22	11	ALONG EASTERN PROPERTY LINE	TBS
6469	CT	CEDAR	24	12	ALONG EASTERN PROPERTY LINE	TBS
6470	DT	CEDAR	20	6	ALONG EASTERN PROPERTY LINE	TBS
6471	DT	POPLAR	20	10	ALONG EASTERN PROPERTY LINE	TBS
6472	DT	SYCAMORE	16	6	ALONG EASTERN PROPERTY LINE	TBS

100 50 0 100 200

GRAPHIC SCALE
SCALE: 1" = 100'

APPROVED
DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR		DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES		
SITE PLAN No. _____		
DIRECTOR		DATE
CHAIRMAN, PLANNING COMMISSION		DATE
DATE RECORDED _____		
INSTRUMENT NO.	DEED BOOK NO.	PAGE NO.



NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN
PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

	MARK	DATE	DESCRIPTION
L 1		12/17/2019	FIRST SUBMISSION
2		03/17/2020	COMPLETENESS COMMENTS
3		04/06/2020	COMPLETENESS RESUBMISSION


PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:

OVERALL EXISTING CONDITIONS & KEY PLAN

SHEET No.

C200



NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN
PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION
MARK	DATE	DESCRIPTION

PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW


SHEET TITLE:

SITE PLAN

SHEET No.

C300

109639



MATCHLINE SEE SHEET C301


A

B

C

D

- NOTES:
1. SEE SHEET C101 FOR LEGEND.
 2. FINAL LOCATION, SIZE AND DESIGN DETAILS OF PUMP STATION WILL BE UNDER SEPARATE PLANS.
 3. ANY DEVELOPMENT IN THE RPA WILL BE PERVIOUS
 4. SEE SHEETS C500-C502 FOR LIMITS OF CLEARING
 5. STREET NAMES MAY CHANGE IN FUTURE AS PART OF FORTHCOMING DSUPS.
 6. FINAL LOCATION OF STREETLIGHTS TO BE DETERMINED AND SHOWN WITH DSUPS/ON FINAL SITE PLAN.
 7. DESIGNS AND COORDINATION OF SIGNALIZED INTERSECTIONS TO BE DONE WITH FINAL SITE PLANS.



APPROVED
DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES


SITE PLAN No. _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____

DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____

christopher consultants
2920 w. broad st.
suite 222
richmond, va 23230
engineering surveying land planning



NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN
PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION



PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: J.L.H.
DRAWING: MM
CHECKED: K.W.W.

SHEET TITLE:


SITE PLAN

SHEET No.

C302



- NOTES:
- 1. SEE SHEET C101 FOR LEGEND.
 - 2. ELECTRICAL VAULTS SHOWN ARE UNDERGROUND.
 - 3. SEE SHEET C101 FOR ARCHAEOLOGY NOTES.
 - 4. FINAL SIZE AND LOCATION OF VAULTS WILL BE DETERMINED WITH DSUP.



APPROVED
DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES
SITE PLAN No. _____

DIRECTOR _____ DATE _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____

DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION


PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: J.L.H.
DRAWN: M.M.
CHECKED: K.M.W.

SHEET TITLE:


UTILITY PLAN

SHEET No. **C402**

christopher consultants
2920 w. broad st.
suite 222
richmond, va 23230
p 804.389.9903
engineering surveying land planning





NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN
PRELIMINARY DEVELOPMENT SITE PLAN
CITY OF ALEXANDRIA, VIRGINIA




PRE-DEVELOPMENT IMPERVIOUS AREA MAP

- BACK-OUT AREA (SEE NOTE #1)
- EXISTING IMPERVIOUS AREA (5.98 AC)
- SITE BOUNDARY



POST-DEVELOPMENT IMPERVIOUS AREA MAP

- BACK-OUT AREA (SEE NOTE #1)
- PROPOSED IMPERVIOUS AREA (6.22 AC)
- SITE BOUNDARY



NOTES:
1.) HATCHED AREAS DEPICT EXISTING SITE AREA TO BE TREATED WITH FULL DEVELOPMENT OF THE SITE AND HAVE NOT BEEN INCLUDED IN EXISTING OR PROPOSED SITE TABULATIONS IN THE VRRM TO DETERMINE REMOVAL REQUIREMENTS. THESE AREAS WILL BE NOTED AS THEIR EXISTING CONDITION FOR THE DSUP PHASE.

APPROVED

DEVELOPMENT SITE PLAN NO. _____

DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____

DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES

SITE PLAN No. _____

DIRECTOR _____ DATE _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____

DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____

christopher consultants

2920 w. broad st.
suite 222
richmond, va 23230

p 804.389.9903

engineering

surveying

land planning

COMMONWEALTH OF VIRGINIA

JOHN L. HELMS

Lic. No. 52485

04/06/2020

PROFESSIONAL ENGINEER

NORTH POTOMAC YARD

PHASE 1 INFRASTRUCTURE PLAN

PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION


PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:

PRE VS. POST
DEVELOPMENT
IMPERVIOUS

SHEET No.
C600

109639



LEGEND:

	BMP DRAINAGE DIVIDE		PERMEABLE PAVEMENT
	LINEAR BIORETENTION AREA		BACKOUT AREA (SEE NOTE #1)

NOTES:

1.) HATCHED AREAS DEPICT EXISTING SITE AREA TO BE TREATED WITH FULL DEVELOPMENT OF THE SITE AND HAVE NOT BEEN INCLUDED IN EXISTING OR PROPOSED SITE TABULATIONS IN THE VRRM TO DETERMINE REMOVAL REQUIREMENTS. THESE AREAS WILL BE NOTED AS THEIR EXISTING CONDITION FOR THE DSUP PHASE.

2.) SEE SHEET C606 FOR INDIVIDUAL DRAINAGE AREAS TO BIORETENTION AND BAYFILTER FACILITIES AND SIZING OF BIORETENTION BASINS.

VIRGINIA STATE GRID NORTH

GRAPHIC SCALE
1"=30'

APPROVED

DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES
SITE PLAN No. _____

DIRECTOR _____ DATE _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____
DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____

MATCHLINE SEE SHEET C604

christopher consultants

2920 W. Broad St.
Suite 222
Richmond, VA 23230

p 804.389.9903
e 804.389.9903

engineering surveying land planning

COMMONWEALTH OF VIRGINIA

JOHN L. HELMS
Lic. No. 52485
04/06/2020

PROFESSIONAL ENGINEER

NORTH POTOMAC YARD

PHASE 1 INFRASTRUCTURE PLAN

PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION


PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: J.L.H.
DRAWN: M.M.
CHECKED: K.M.W.

SHEET TITLE:

SWM-BMP PLAN

SHEET No.


C603



LEGEND:

	BMP DRAINAGE DIVIDE		PERMEABLE PAVEMENT
	LINEAR BIORETENTION AREA		BACKOUT AREA (SEE NOTE #1)

NOTES:
1.) HATCHED AREAS DEPICT EXISTING SITE AREA TO BE TREATED WITH FULL DEVELOPMENT OF THE SITE AND HAVE NOT BEEN INCLUDED IN EXISTING OR PROPOSED SITE TABULATIONS IN THE VRRM TO DETERMINE REMOVAL REQUIREMENTS. THESE AREAS WILL BE NOTED AS THEIR EXISTING CONDITION FOR THE DSUP PHASE.
2.) FUTURE CONNECTION FOR GROUNDWATER
3.) SEE SHEET C606 FOR INDIVIDUAL DRAINAGE AREAS TO BIORETENTION AND BAYFILTER FACILITIES AND SIZING OF BIORETENTION BASINS.



APPROVED
DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR	DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES	
SITE PLAN No. _____	
DIRECTOR	DATE
CHAIRMAN, PLANNING COMMISSION	DATE
DATE RECORDED	
INSTRUMENT NO.	DEED BOOK NO.
PAGE NO.	

christopher consultants
2920 w. broad st.
suite 222
richmond, va 23230
p 804.389.9903
engineering surveying land planning

NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN
PRELIMINARY DEVELOPMENT SITE PLAN
CITY OF ALEXANDRIA, VIRGINIA

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION

PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:

SWM-BMP PLAN

SHEET No.

C604


6

Bioretention #21	
Impervious DA (AC)	0.21
Managed DA (AC)	0.05
Treatment Volume (CF)	770
Minimum Area (SF)	670
Actual Area (SF)	2264
Upstream BMP	None
Downstream BMP	None

C607

C607

FOR INFORMATIONAL PURPOSES ONLY



VIRGINIA STATE GRID NORTH

christopher consultants

2920 W. Broad St.
Suite 222
Richmond, VA 23230

engineering surveying land planning

COMMONWEALTH OF VIRGINIA

JOHN L. HELMS
Lic. No. 52485
04/06/2020

PROFESSIONAL ENGINEER

NORTH POTOMAC YARD

PHASE 1 INFRASTRUCTURE PLAN

PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

1	12/17/2019	FIRST SUBMISSION	COMPLETENESS COMMENTS	COMPLETENESS RESUBMISSION	MARK	DATE	DESCRIPTION
2	03/17/2020						
3	04/06/2020						

APPROVED

DEVELOPMENT SITE PLAN NO. _____

DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____

DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES

SITE PLAN No. _____

DIRECTOR _____ DATE _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____

DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____

PROJECT No.: 88024.172.02

DRAWING No.: 109639

DATE: 2020-04-06

DESIGN: JLH

DRAWN: MM

CHECKED: KMW

SHEET TITLE:

SANITARY SEWER PLAN

SHEET No.

C700


A


ONSITE SANITARY SEWER HGL COMPUTATIONS

109639


FOR INFORMATIONAL PURPOSES ONLY

EXISTING SANITARY SEWER PIPE COMPUTATIONS
(PHASE I)

<div>Christopher consultants</div> <div>ULTIMATE BUILD-OUT FLOWS</div> <div>PHASE I - DRAFT</div>															Project Number: 88024.172.02 Prepared by: Mustafa Mahmoudi, P.E., CFM Checked by: Kevin Washington Date Prepared: 2/11/2020									
24" Gravity Sewer - S16 to S33 (Potomac Ave)															Use Total Sanitary Sewer Flow Computations (Trunk Line)									
FROM		TO		UPPER INV	LOWER INV	L (FT)	SLOPE (%)	DIA (IN)	MATERIAL	N	CAPACITY (cfs)	CAPACITY (MGD)	DESIGN FLOW (cfs)	DESIGN FLOW (MGD)	AVAILABLE CAPACITY (CFS)	AVAILABLE CAPACITY (MGD)	V _{full} (ft/s)	Assumptions	Inc					
design		S16	S15	27.74	27.15	14.30	4.13	24	PVC	0.011	54.31	35.10	7.85	5.07	46.46	30.03	17.29	4 mile run and North Potomac Yard Phase I	5.07					
design		S15	S14	27.05	23.83	397.20	0.81	24	PVC	0.011	24.07	15.56	7.85	5.07	16.23	10.49	7.66	Landbay G	1.04					
design		S14	S13	23.58	22.75	251.80	0.33	24	PVC	0.011	15.35	9.92	9.60	6.21	5.75	3.71	4.89	Fire Station and Landbay H	5.07					
design		S13	S12	22.65	21.81	254.20	0.33	24	PVC	0.011	15.37	9.93	11.15	7.21	4.22	2.73	4.89		1.00					
design		S12	S11	21.71	21.02	210.10	0.33	24	PVC	0.011	15.32	9.90	11.15	7.21	4.17	2.70	4.88							
design		S11	S10	20.92	20.10	246.40	0.33	24	PVC	0.011	15.42	9.97	11.15	7.21	4.27	2.76	4.91							
design		S10	S9A	20.00	19.33	203.40	0.33	24	PVC	0.011	15.35	9.92	11.15	7.21	4.19	2.71	4.88							
design		S9A	S9	19.23	18.88	107.80	0.32	24	PVC	0.011	15.24	9.85	11.15	7.21	4.08	2.64	4.85							
design		S9	S8	18.78	17.99	237.00	0.33	24	PVC	0.011	15.44	9.98	11.15	7.21	4.29	2.77	4.91							
design		S8	S7A	17.89	17.25	195.00	0.33	24	PVC	0.011	15.32	9.90	11.52	7.45	3.79	2.45	4.88	Landbay I	0.24					
design		S7A	S7	17.15	16.67	146.90	0.33	24	PVC	0.011	15.28	9.88	11.52	7.45	3.76	2.43	4.86							
design		S7	S6	16.57	16.09	144.00	0.33	24	PVC	0.011	15.44	9.98	11.52	7.45	3.97	2.53	4.91							
design		S6	S5	15.99	15.23	230.30	0.33	24	PVC	0.011	15.36	9.93	11.52	7.45	3.84	2.48	4.89							
design		S5	S4	15.13	14.32	244.40	0.33	24	PVC	0.011	15.39	9.95	11.52	7.45	3.87	2.50	4.90							
design/as-built		S4	S3	14.22	13.83	74.40	0.52	24	PVC	0.011	19.36	12.51	14.17	9.16	5.19	3.35	6.16	Landbay J, Oakville Triangle, and River RD	1.71					
as-built		S3	S2	13.73	13.29	124.20	0.35	24	PVC	0.011	15.91	10.29	14.17	9.16	1.75	1.13	5.07							
as-built/design slope		S2	S33A (PUMP)	13.19	12.70	151.90	0.32	24	PVC	0.011	15.19	9.81	14.17	9.16	1.02	0.66	4.83	On-site pump station, Calculated normal depth = 1.80', Max Flow = 17.89 cfs						
as-built/design slope		S33A	S33B	--	--	--	--	24	PVC	0.011	--	--	14.17	9.16	--	--	--	Force Main						
as-built/design slope		S33B	S33	--	--	--	--	24	PVC	0.011	--	--	14.17	9.16	--	--	--	Force Main						
27" Gravity Sewer - S33 to S24 (Potomac Ave)															Use Total Sanitary Sewer Flow Computations (Trunk Line)									
FROM		TO		UPPER INV	LOWER INV	L (FT)	SLOPE (%)	DIA (IN)	MATERIAL	N	CAPACITY (cfs)	CAPACITY (MGD)	DESIGN FLOW (cfs)	DESIGN FLOW (MGD)	AVAILABLE CAPACITY (CFS)	AVAILABLE CAPACITY (MGD)	V (ft/s)	Assumptions	Inc					
as-built		S33	S32	27.23	26.37	300.50	0.29	27	PVC	0.011	19.58	12.66	15.34	9.92	4.24	2.74	4.92	Slater's lane pump station and Landbay C	0.76					
as-built		S32	S31A	26.28	25.56	237.50	0.30	27	PVC	0.011	20.15	13.03	15.34	9.92	4.81	3.11	5.07							
as-built		S31A	S31	25.45	25.02	133.00	0.32	27	PVC	0.011	20.81	13.45	15.34	9.92	5.47	3.53	5.23							
as-built		S31	S30	24.89	24.41	173.00	0.28	27	PVC	0.011	19.28	12.46	15.34	9.92	5.94	2.54	4.85							
as-built		S30	S29A	24.34	23.34	295.00	0.33	27	PVC	0.011	20.88	13.50	15.34	9.92	5.54	3.58	5.25							
as-built		S29A	S29	23.29	22.60	39.50	1.75	27	PVC	0.011	48.38	31.27	15.34	9.92	33.03	21.35	12.17							
as-built		S29	S28	22.57	22.08	140.00	0.35	27	PVC	0.011	21.66	14.00	15.34	9.92	6.31	4.08	5.45							
as-built		S28	S27	21.93	21.14	209.50	0.38	27	PVC	0.011	22.48	14.53	15.34	9.92	7.13	4.61	5.65							
as-built		S27	S26	21.09	20.10	402.00	0.25	27	PVC	0.011	18.16	11.74	15.82	10.23	2.84	1.51	4.57	Landbay L	0.91					
as-built		S26	S25	19.90	19.33	197.50	0.29	27	PVC	0.011	19.66	12.71	15.82	10.23	3.84	2.48	4.95							
as-built		S25	S24	19.21	18.28	276.00	0.34	27	PVC	0.011	21.25	13.73	15.82	10.23	5.42	3.51	5.34							
30" Gravity Sewer - Shaft 24 to Shaft 0 (Off-Site)															Use Total Sanitary Sewer Flow Computations (Trunk Line)									
FROM		TO		UPPER INV	LOWER INV	L (FT)	SLOPE (%)	DIA (IN)	MATERIAL	N	CAPACITY (cfs)	CAPACITY (MGD)	DESIGN FLOW (cfs)	DESIGN FLOW (MGD)	AVAILABLE CAPACITY (CFS)	AVAILABLE CAPACITY (MGD)	V (ft/s)	Contributing Flows						
as-built		24	23	18.26	17.7	281.2	0.20	30	CCFP	0.011	21.63	13.98	15.82	10.23	5.81	3.75	4.41							
as-built		23	22	17.51	16.97	221.8	0.24	30	CCFP	0.011	22.92	15.46	15.82	10.23	8.10	5.23	4.87							
as-built		22	21	16.83	15.94	253.2	0.35	30	CCFP	0.011	28.74	18.58	15.82	10.23	12.92	8.35	5.86							
as-built		21	20	15.85	14.84	376.3	0.27	30	CCFP	0.011	25.12	16.23	15.82	10.23	9.29	6.01	5.12							
as-built		20	19	14.67	13.73	394.3	0.24	30	CCFP	0.011	23.67	15.30	15.82	10.23	4.40	2.84	4.82	Braddock Metro Neighborhood Plan	2.23					
as-built		19	18	13.46	12.47	427	0.23	30	CCFP	0.011	23.34	15.09	19.27	12.45	4.07	2.63	4.76							
as-built		18	17	12.12	11.01	424.4	0.26	30	CCFP	0.011	24.79	16.02	19.27	12.45	5.52	3.57	5.05							
as-built		17	16	10.75	10.06	410.9	0.17	30	CCFP	0.011	19.87	12.84	20.94	13.54	-1.08	-0.70	4.05	Existing Developments and Separation Completed by December 2019	1.08					
as-built		16	15	9.71	8.97	416.8	0.18	30	CCFP	0.011	20.43	13.20	20.94	13.54	-0.52	-0.33	4.16							
as-built		15	14	8.66	7.49	430.1	0.27	30	CCFP	0.011	25.28	16.34	20.94	13.54	4.34	2.81	5.15							
as-built		14	13	7.43	6.62	340.8	0.24	30	CCFP	0.011	23.63	15.28	20.94	13.54	2.69	1.74	4.81							
as-built		13	12	6.52	5.6	315.4	0.29	30	CCFP	0.011	26.18	16.98	22.65	14.64	3.53	2.28	5.33							
as-built		12	11	5.55	4.49	326.4	0.32	30	CCFP	0.011	27.63	17.86	22.65	14.64	4.97	3.22	5.63	Remaining Separation	1.104					
as-built		11	10	4.39	3.21	434.6	0.27	30	CCFP	0.011	25.26	16.33	22.65	14.64	2.61	1.69	5.15							
as-built		10	9	2.98	1.77	451.20	0.28	30	CCFP	0.011	25.88	16.60	22.65	14.64	3.03	1.96	5.25							
as-built		9	8	1.51	0.53	451.20	0.34	30	CCFP	0.011	28.22	18.24	22.65	14.64	5.60	3.40	5.75							
as-built		8	7	0.46	0.05	400.90	0.30	30	CCFP	0.011	15.50	10.02	22.65	14.64	-7.15	-4.62	3.16							
as-built		7	5	0.01	-2.17	587.20	0.37	30	CCFP	0.011	29.54	19.09	22.65	14.64	6.89	4.45	6.02							
as-built		6	5	-0.45	-2.78	461.10	0.27	30	CCFP	0.011	24.40	16.41	22.65	14.64	5.17	3.17	5.40							
as-built		4	3	-3.83	-4.64	399.00	0.20	30	CCFP	0.011	21.84	14.12	22.65	14.64	-0.81	-0.52	4.45							
as-built		3	2	-4.74	-5.89	408.70	0.28	30	CCFP	0.011	25.72	16.62	22.65	14.64	3.06	1.98	5.24							
as-built		2	1	-6.38	-7.14	326.60	0.23	30	CCFP	0.011	23.89	15.11	22.65	14.64	0.73	0.47	4.76							
as-built/design slope		1	0	-7.28	-7.50	80.30	0.27	30	CCFP	0.011	25.37	16.40	22.65	14.64	2.72	1.76	5.17							
Note: All calculated capacities are at full flow capacity, when the slope is approximately 93% full.																								



THIS SHEET IS PROVIDED FOR INFORMATIONAL PURPOSES ONLY!



NOTES:
1. SANITARY SEWER FLOWS SHOWN
ARE AVERAGE DAILY FLOWS
LEGEND:
EX SANITARY TRUNK SEWER

APPROVED

DEVELOPMENT SITE PLAN NO. _____

DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____

DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES

SITE PLAN No. _____

DIRECTOR _____ DATE _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____

DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____

christopher consultants

2920 W. Broad St.
Suite 222
Richmond, VA 23230

engineering surveying land planning

COMMONWEALTH OF VIRGINIA

JOHN L. HELMS

Lic. No. 52485

04/06/2020

PROFESSIONAL ENGINEER

NORTH POTOMAC YARD

PAHSE 1 INFRASTRUCTURE PLAN

PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VA

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION

PROJECT No.: 88024.172.02

DRAWING No.: 109639

DATE: 2019-12-17

DESIGN: JLH

DRAWN: MM

CHECKED: KMW

SHEET TITLE:

EX. 30" OFFSITE SAN. TRUNK SEWER

SHEET No.

C703



10%39

D

C

B

A




NOTE:

PROPOSED INTERSECTIONS IN THE SITE ARE "ALL-WAY STOP CONTROL". BASED ON AASHTO GREEN BOOK THEY ARE CATEGORIZED AS CASE E.

CASE E: AT INTERSECTIONS WITH ALL-WAY STOP CONTROL, THE FIRST STOPPED VEHICLE ON ONE APPROACH SHOULD BE VISIBLE TO THE DRIVERS OF THE FIRST STOPPED VEHICLES ON EACH OF THE OTHER APPROACHES.

SEE SITE PLAN SHEETS FOR "75' VISION TRIANGLES" WHICH MEET AND EXCEED THIS REQUIREMENT.




SIGHT DISTANCE AT INTERSECTION OF POTOMAC AVE. AND SILVER METEOR AVE.

AASHTO GREEN BOOK
CASE B - INTERSECTION WITH STOP CONTROL ON THE MINOR ROAD

MAJOR ROAD:
POTOMAC AVENUE
EXISTING 4-LANE HIGHWAY
SPEED LIMIT = 25 MPH

MINOR ROAD:
PROP. SILVER METEOR AVE. WITH STOP CONTROL



APPROVED

DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES
SITE PLAN No. _____


DIRECTOR _____ DATE _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____

DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____

christopher consultants
2920 w. broad st.
suite 222
richmond, va 23230
p 804.389.9903
engineering surveying land planning



NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN
PRELIMINARY DEVELOPMENT SITE PLAN
CITY OF ALEXANDRIA, VIRGINIA

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION



PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:

**SIGHT DISTANCE
PLAN & PROFILE**

SHEET No.

C802




NOTE:

PROPOSED INTERSECTIONS IN THE SITE ARE "ALL-WAY STOP CONTROL". BASED ON AASHTO GREEN BOOK THEY ARE CATEGORIZED AS CASE E.

CASE E: AT INTERSECTIONS WITH ALL-WAY STOP CONTROL, THE FIRST STOPPED VEHICLE ON ONE APPROACH SHOULD BE VISIBLE TO THE DRIVERS OF THE FIRST STOPPED VEHICLES ON EACH OF THE OTHER APPROACHES.

SEE SITE PLAN SHEETS FOR "75' VISION
TRIANGLES" WHICH MEET AND EXCEED THIS
REQUIREMENT.




SIGHT DISTANCE AT INTERSECTION OF
POTOMACE AVE. AND STREET "A".

AASHTO GREEN BOOK
CASE B - INTERSECTION WITH STOP CONTROL
ON THE MINOR ROAD

MAJOR ROAD:
POTOMAC AVENUE
EXISTING 4-LANE HIGHWAY
SPEED LIMIT = 25 MPH

MINOR ROAD:
PROP. STREET "A" WITH STOP CONTROL



APPROVED

DEVELOPMENT SITE PLAN NO.

DEPARTMENT OF PLANNING & ZONING

DIRECTOR

DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES
SITE PLAN No. _____

DIRECTOR

CHAIRMAN, PLANNING COMMISSION DAT

DATE RECORDED


INSTRUMENT NO. DEED BOOK NO. PAGE NO.



christopher
consultants

2920 w. broad st. p 804.389.9903
suite 222
richmond, va 23230

engineering surveying land planning



NORTH POTOMAC YARD

PHASE 1 INFRASTRUCTURE PLAN

PRELIMINARY DEVELOPMENT SITE PLAN

MARK	DATE	DESCRIPTION
1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION


PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:

SIGHT DISTANCE PLAN & PROFILE

SHEET No.

C804






christopher
consultants

2920 w. broad st. p 804.389.9903
suite 222 richmond, va 23230

engineering surveying land planning



NORTH POTOMAC YARD
PHASE 1 INFRASTRUCTURE PLAN
PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

FIRST SUBMISSION			COMPLETENESS COMMENTS			COMPLETENESS RESUBMISSION			DESCRIPTION		
1	2	3	12/17/2019	03/17/2020	04/06/2020				MARK	DATE	

PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:

**TURNING
MOVEMENTS**

SHEET No.

C900

- NOTES:
1. VEHICLE DIMENSIONS SOURCED FROM 100' RSMP AERIAL LADDER AND BODY ASSEMBLY NO PUMP-NO TANK DETAIL FOR FAIRFAX COUNTY FIRE & RESCUE DEPARTMENT.

APPROVED

DEVELOPMENT SITE PLAN NO. _____

DEPARTMENT OF PLANNING & ZONING

DIRECTOR _____ DATE _____

DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES


SITE PLAN No. _____




DIRECTOR _____ DATE _____

CHAIRMAN, PLANNING COMMISSION _____ DATE _____


DATE RECORDED _____

INSTRUMENT NO. _____ DEED BOOK NO. _____ PAGE NO. _____





BUS-45 - Inter City Bus	
Overall Length	45.500ft
Overall Width	8.500ft
Overall Body Height	12.008ft
Min Body Ground Clearance	1.158ft
Track Width	8.500ft
Lock-to-lock time	5.00s
Max Steering Angle (Virtual)	45.20°



BUS CLEARANCE
NTS

<h1 style="margin: 0;">APPROVED</h1>		
DEVELOPMENT SITE PLAN NO. _____		
DEPARTMENT OF PLANNING & ZONING		
_____ DIRECTOR	_____ DATE	
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES		
SITE PLAN No. _____		
_____ DIRECTOR	_____ DATE	
CHAIRMAN, PLANNING COMMISSION		
DATE RECORDED _____		
INSTRUMENT NO. _____	DEED BOOK NO. _____	PAGE NO. _____

1	12/17/2019	FIRST SUBMISSION
2	03/17/2020	COMPLETENESS COMMENTS
3	04/06/2020	COMPLETENESS RESUBMISSION
MARK	DATE	DESCRIPTION


PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:


TURNING MOVEMENTS

SHEET No.

C901



christopher
consultants
2920 w. broad st.
suite 222
richmond, va 23230
p 804.389.9903
surveying land planning




NORTH POTOMAC YARD

PHASE 1 INFRASTRUCTURE PLAN

PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA






christopher
consultants

2920 w. broad st.
suite 222
richmond, va 23230

engineering surveying land planning



COMMONWEALTH OF VIRGINIA
JOHN L. HELMS
Lic. No. 52485
04/06/2020
PROFESSIONAL ENGINEER

NORTH POTOMAC YARD

PHASE 1 INFRASTRUCTURE PLAN

PRELIMINARY DEVELOPMENT SITE PLAN

CITY OF ALEXANDRIA, VIRGINIA

FIRST SUBMISSION			COMPLETENESS COMMENTS			COMPLETENESS RESUBMISSION			DESCRIPTION		
1	2	3	12/17/2019	03/17/2020	04/06/2020				MARK	DATE	

PROJECT No.: 88024.172.02
DRAWING No.: 109639
DATE: 2020-04-06
DESIGN: JLH
DRAWN: MM
CHECKED: KMW

SHEET TITLE:

TURNING
MOVEMENTS

SHEET No.
C904



NORTH POTOMAC YARD

Phase 1 - Open Space
Concept 1 Plan

Client
**CPYR SHOPPING CENTER &
CPYR THEATER LLC**
712 Main Street, Suite 2500
Houston, Texas 77002

OJB Landscape Architecture
One Bowdoin Square, Suite 801
Boston, Massachusetts 02114
tel 857.233.5171

Development Manager
JBG Smith
4445 Willard Ave, Suite 400
Chevy Chase, Maryland 20815
tel 240.333.3600

Master Planner
Elkus Manfredi Architects
25 Drydock Avenue
Boston, Massachusetts 02210
tel 617.426.1300

Civil Engineer
Christopher Consultants, Ltd.
9900 Main Street, 4th Floor
Fairfax, Virginia 22031
tel 703.273.6820


Traffic Engineer
Kimley Horn
11400 Commerce Park Drive, Suite 400
Reston, Virginia 20191
tel 703.674.1300

Attorney
Walsh, Colucci, Lubely, & Walsh
Courthouse Plaza
2200 Clarendon Boulevard, Suite 1300
Arlington, VA 22201
tel 703.528.4700



**OJB | THE OFFICE OF
JAMES BURNETT**
LANDSCAPE ARCHITECTURE
ONE BOWDOIN SQUARE,
SUITE 801
BOSTON, MA 02114
T 857.233.5171
WWW.OJB.COM


KEY MAP



REV. DATE DESCRIPTION

Job Number: PT-YRD
Issue Date: 17 March 2020

Scale: 1" = 100'-0"




PHASE 1 OPEN SPACE PLAN

A1

These drawings are instruments of service. The Office of James Burnett shall retain all copyrights, patents and common law rights with regard to these drawings and the design content therein in all formats, including printed and digital. These drawings are not to be altered in any way, nor adapted to a third party without the following written permission and consent from The Office of James Burnett.
© 2020 THE OFFICE OF JAMES BURNETT

FOR INFORMATIONAL PURPOSES ONLY



NOTE: Street names are subject to change through the DSUP process with a street name application to be submitted at a later date.

ELKUS | MANFREDI

ARCHITECTS

[address] 25 DRYDOCK AVENUE
BOSTON MASSACHUSETTS 02210
[tel] 617.426.1300

OWNER / APPLICANT

CPYR SHOPPING CENTER LLC & CPYR
THEATER LLC
100 WAUGHT DRIVE, SUITE 600
HOUSTON, TEXAS 77007

CONSULTANTS

DEVELOPMENT MANAGER

JBG SMITH
4445 WILLARD AVE, SUITE 400
CHEVY CHASE, MARYLAND 20815
240.333.3600

CIVIL ENGINEER

christopher consultants, ltd.
9900 MAIN STREET, 4TH FLOOR
FAIRFAX, VIRGINIA 22031
703.273.6820

TRAFFIC ENGINEER

KIMLEY-HORN
11400 COMMERCE PARK DRIVE, SUITE 400
RESTON, VIRGINIA 20191
703.674.1300

ATTORNEY

WALSH, COLUCCI, LUBELY & WALSH
COURTHOUSE PLAZA
2200 CLARENDON BOULEVARD, STE 1300
ARLINGTON, VA 22201
703.528.4700

ISSUANCES / REVISIONS

#	DESCRIPTION	DATE
1	CONCEPTUAL DESIGN PLAN AMENDMENT	11/1/2019

PROFESSIONAL SEAL

PROFESSIONAL CERTIFICATION:
I HEREBY CERTIFY THAT THESE DOCUMENTS
WERE PREPARED OR APPROVED BY ME, AND
THAT I AM A DULY LICENSED PROFESSIONAL
ARCHITECT UNDER THE LAWS OF THE STATE
VIRGINIA

LICENSE NO:0401013798 EXP:06/30/2020

POTOMAC YARD
NORTH
CONCEPTUAL
DESIGN PLAN
AMENDMENT

ALEXANDRIA, VIRGINIA

PHASE 1 INTERIM
TRANSPORTATION
PLAN

A2

PROJECT NUMBER

19-249

DATE

03/17/2020

MANAGED BY



KMD

DRAWN BY


HDS

SCALE

1" = 100'-0"



SCALE: $1/4" = 1'-0"$




<h1 style="text-align: center;">APPROVED</h1> <p>DEVELOPMENT SITE PLAN NO. _____</p> <p>DEPARTMENT OF PLANNING & ZONING</p>		
<p style="text-align: center;">DIRECTOR</p>		<p style="text-align: center;">DATE</p>
<p>DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES</p> <p>SITE PLAN No. _____</p>		
<p style="text-align: center;">DIRECTOR</p>		<p style="text-align: center;">DATE</p>
<p>CHAIRMAN, PLANNING COMMISSION</p>		<p style="text-align: center;">DATE</p>
<p>DATE RECORDED _____</p>		
<p>INSTRUMENT NO.</p>	<p>DEED BOOK NO.</p>	<p>PAGE NO.</p>

NORTH POTOMAC YARD
PUMP STATION
ALEXANDRIA, VIRGINIA

SCALE: AS SHOWN	
DATE: MARCH 16, 2019	
DESIGN:	BMJ
DRAWN:	BMJ
CHECKED:	EL
SHEET No. P-1 1 OF 6	

 ***Gannett Fleming***
BALTIMORE, MARYLAND



Gannett Fleming
BALTIMORE, MARYLAND

COMMONWEALTH OF VIRGINIA
ELIEZER LIVAY
Lic. No. 053949
Professional Engineer

PROCESS
PUMP STATION
LOWER LEVEL PLAN

NORTH POTOMAC YARD
PUMP STATION
ALEXANDRIA, VIRGINIA

SCALE:
AS SHOWN

DATE:
MARCH 16, 2019

DESIGN: BMJ
DRAWN: BMJ
CHECKED: EL

SHEET No.
P-2
2 OF 6



APPROVED
DEVELOPMENT SITE PLAN NO. _____
DEPARTMENT OF PLANNING & ZONING

DIRECTOR DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES
SITE PLAN No. _____

DIRECTOR DATE

CHAIRMAN, PLANNING COMMISSION DATE
DATE RECORDED _____

INSTRUMENT NO. DEED BOOK NO. PAGE NO.



1 PUMP STATION SECTION
SCALE: 1/4" = 1'-0"

30% Design
Not for Construction

APPROVED	
DEVELOPMENT SITE PLAN NO. _____	
DEPARTMENT OF PLANNING & ZONING	
DIRECTOR	DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES	
SITE PLAN No. _____	
DIRECTOR	DATE
CHAIRMAN, PLANNING COMMISSION	
DATE RECORDED _____	
INSTRUMENT NO.	DEED BOOK NO.
PAGE NO.	

BALTIMORE, MARYLAND

COMMONWEALTH OF VIRGINIA
ELIEZER LIVAY
Lic. No. 053949
Professional Engineer

PROCESS
PUMP STATION
SECTION


NORTH POTOMAC YARD
PUMP STATION
ALEXANDRIA, VIRGINIA

SCALE:
AS SHOWN


DATE:
MARCH 16, 2019

DESIGN: BMJ
DRAWN: BMJ
CHECKED: EL

SHEET No.
P-3
3 OF 6




2 P-4 PUMP STATION SECTION
SCALE: 1/4" = 1'-0"



30% Design
Not for Construction



APPROVED	
DEVELOPMENT SITE PLAN NO. _____	
DEPARTMENT OF PLANNING & ZONING	
DIRECTOR	DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES	
SITE PLAN No. _____	
DIRECTOR	DATE
CHAIRMAN, PLANNING COMMISSION	
DATE RECORDED _____	
INSTRUMENT NO.	DEED BOOK NO.
PAGE NO.	



PROCESS
PUMP STATION
SECTION

NORTH POTOMAC YARD
PUMP STATION
ALEXANDRIA, VIRGINIA


SCALE:
AS SHOWN
DATE:
MARCH 16, 2019
DESIGN: BMJ
DRAWN: BMJ
CHECKED: EL
SHEET No.
P-4
4 OF 6




3 PUMP STATION SECTION
P-5 SCALE: 1/4" = 1'-0"

30% Design
Not for Construction

APPROVED	
DEVELOPMENT SITE PLAN NO. _____	
DEPARTMENT OF PLANNING & ZONING	
DIRECTOR	DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES	
SITE PLAN No. _____	
DIRECTOR	DATE
CHAIRMAN, PLANNING COMMISSION	
DATE RECORDED	
INSTRUMENT NO.	DEED BOOK NO.
PAGE NO.	

**Gannett Fleming**
BALTIMORE, MARYLAND



PROCESS
PUMP STATION
SECTION


NORTH POTOMAC YARD
PUMP STATION
ALEXANDRIA, VIRGINIA

SCALE:
AS SHOWN

DATE:
MARCH 16, 2019

DESIGN: BMJ
DRAWN: BMJ
CHECKED: EL

SHEET No.
P-5
5 OF 6



ONE-LINE DIAGRAM
SCALE: NTS

APPROVED	
DEVELOPMENT SITE PLAN NO. _____	
DEPARTMENT OF PLANNING & ZONING	
DIRECTOR	DATE
DEPT. OF TRANSPORTATION & ENVIRONMENTAL SERVICES	
SITE PLAN No. _____	
DIRECTOR	DATE
CHAIRMAN, PLANNING COMMISSION	
DATE RECORDED _____	
INSTRUMENT NO.	DEED BOOK NO.
PAGE NO.	

30% Design
Not for Construction

North Potomac Yard

Pump Station

Preliminary Engineering Report

Location

Potomac Avenue south of Four Mile Run
Potomac Yard, Alexandria, VA

Prepared For

City of Alexandria and AlexRenew

Prepared By



Gannett Fleming

March 16, 2020

Table of Contents

Executive Summary.....	1
Background and Purpose	1
Service Area	1
Hydraulic Design Requirements.....	1
Recommendations	1
Project Schedule	2
Introduction	3
Purpose	3
Scope.....	3
Project Background.....	3
Existing Facilities	4
Existing Site	4
Impacts on Downstream Facilities	4
Proposed Facility	4
Service Area	4
Project Phasing.....	4
Facility Layout	4
Technical Design	6
Pumps and Process Piping	6
Force Main	7
Wet Well	7
Screening System	8
Civil and Site.....	8
Architectural	9
Structural	9
Odor Control	10
HVAC and Plumbing	10
Fire Protection	12
Electrical.....	12
Generator.....	12
Instrumentation and Control	12
Construction Phasing	13

Appendices.....	14
A. Calculations.....	14
B. Cut Sheets	14
C. Influent Flow Calculations and Documentation.....	14

Executive Summary

Background and Purpose

A new mixed-use development for the VA Tech campus is proposed in the area of Potomac Avenue, south of Four Mile Run, in Alexandria, VA. The current development on the site will be removed to make way for the new development. Wastewater from the current development on the site flows to an existing pump station that will be unable to handle the flows from the proposed new development. Per the City of Alexandria, the existing pump station shall not be upgraded to accept the proposed flows, and a new pump station shall be provided by the developer to meet the demands of the future development. The new pump station will be designed to the satisfaction of VA Tech, the City of Alexandria, and Alexandria Renew Enterprises (AlexRenew), who will operate and maintain the new pump station.

Service Area

The existing site includes a single-story retail development of approximately 600,000 square feet. The proposed development will be a mixed-use development of 7,675,000 square feet. Phase 1 of the development will provide for 1,905,500 square feet. Site plan(s) and breakdown of the usage are included in Appendix C (to be provided later).

Hydraulic Design Requirements

Phase 1 design flow for the proposed pump station is 0.32 MGD average daily flow and 1.07 MGD peak flow. Build-out (Phase 1 and Phase 2) design flow is 2.29 MGD average and 7.10 MGD peak. The pump station will be designed to accommodate flow for all phases from Phase 1 through build-out, and operation sequence will be considered accordingly. A breakdown of the flows is included in Appendix C (to be provided later).

Recommendations

The new pump station will be rated for approximately 7.1 MGD peak flow. The pump station will be a self-cleaning type wet well and dry well configuration. The aboveground structure will be approximately 95 feet by 45 feet. The pump station will include an influent channel with a mechanically cleaned bar screen, a self-cleaning trench-type wet well, and four dry pit submersible pumps each rated for approximately 75 HP. To accommodate initial Phase 1 flow, only two of the pumps will be installed. One pump will handle the Phase 1 peak flow, and the second pump will be used as a backup. Motors with variable speed pump drives (VFDs) will adjust pump speed to accommodate the low initial flows. To accommodate build-out flow after Phase 2, the impellers will be upgraded on the first two pumps, and two additional pumps will be installed. Three pumps will be used to convey the peak flow (firm capacity) and one pump will be provided as a backup.

The interior depth of the wet well will be approximately 48 feet below final grade. The pump station structure will include a permanent emergency power generator fueled by diesel in a dedicated room. Ventilation and odor control will be provided for the pump station. Pump station access will be via exterior doors to the pump room, generator room, and bar screen room. Stairways will provide personnel access to the dry well and the wet well operating floors.

For Phase 1, the pump station will discharge via a proposed 16-inch force main that will extend from the pump station and run south in Potomac Avenue to an existing gravity sanitary system at a manhole (S16) near East Glebe Road. From there, the existing sanitary sewer will drain to the existing Potomac Yard Pump Station to the south of the site. The discharge from the existing pump station flows to the AlexRenew treatment plant. Options for handling the Phase 2 discharge from the proposed pump station will be further evaluated, but it is anticipated that a 20-inch force main will be used to convey the flows from the new pump station to existing manhole S33.

Project Schedule

In order to have the pump station completed by Spring 2023, the following design schedule has been proposed:

- PER and 30% design submittal – 3/16/2020
- 30% design review meeting – 3/31/2020
- 60% design submittal – 5/18/2020
- 60% design review meeting – 6/2/2020
- 90% design submittal – 8/31/2020
- 90% design review meeting – 9/15/2020
- Startup and commissioning plan – 10/12/2020
- 100% (Final) design submittal – 11/2/2020
- 100% (Final) design, startup and commissioning plan review meeting – 11/17/2020

A construction duration of 18 months is anticipated for the pump station.

Introduction

Purpose

The proposed North Potomac Yard mixed-use development will include residential, office, retail, and educational facilities totaling 7,675,000 square feet. This development will eventually replace the existing 600,000 square-foot single-story retail development currently located on the site.

Wastewater from the existing site currently flows to an existing pump station that will be unable to handle the flow from the future development. Per the City of Alexandria, the existing pump station shall not be upgraded to handle the proposed flows, and a new pump station shall be provided by the developer to meet the demands of the future development.

The site will be developed in two phases. Both phases will include the same mix of uses, but the first phase will only provide for 1,905,500 square feet. The new pump station will be needed by the first phase of development. Site plan(s) and breakdown of the usage are included in Appendix C (to be provided later).

Scope

This Preliminary Engineering Report (PER) has been developed in accordance with Virginia Department of Environmental Quality (VDEQ) Sewage Collection and Treatment Requirements and AlexRenew's Pump Station and Force Main Design Guidelines.

Project Background

The North Potomac Yard Pump Station (NPYPS) will be constructed to serve sanitary sewer flows from the proposed North Potomac Yard mixed-use development. The sanitary system will flow by gravity to the proposed pump station, which will be located at the north end of the site.

For Phase 1, the proposed pump station will discharge via a proposed 16-inch force main that will extend south along Potomac Avenue to an existing gravity sanitary system at a manhole (S16) near the intersection of Potomac Avenue and East Glebe Road. From there, it will flow by gravity to the existing Potomac Yard Pump Station near the intersection of Potomac Avenue and East Howell Avenue. It is not anticipated that the existing Potomac Yard Pump Station will need to be upgraded with Phase 1 of development. The existing pump station discharges to a gravity system that flows to the AlexRenew treatment plant located at 1800 Limerick St, Alexandria, VA. The AlexRenew plant discharges treated effluent into the Potomac River via Hunting Creek.

Additional options for the proposed pump station force main will be evaluated for Phase 2 flows.

Existing Facilities

Existing Site

The current site includes an existing single-story retail development with approximately 600,000 square feet and is zoned per the current CDD #19. The site is bordered to the west by Route 1, to the south by East Glebe Road, to the east by the CSX railway tracks, and to the north by the Four Mile Run tributary to the Potomac River. Per the FEMA flood maps, this site is located in an area of minimal flood hazard.

Impacts on Downstream Facilities

The proposed onsite pump station at the north end of the site will collect and convey the wastewater generated onsite from Phase 1 to the Potomac Yard Pump Station to the south. Upgrades to the existing pump station or the offsite trunk sewers will not be required with the first phase of development. Impacts to the downstream facilities and subsequent mitigations to accommodate Phase 2 of the development are currently under evaluation and will be determined in the near future. Sanitary sewer collection, conveyance, and treatment will be provided by the City of Alexandria and AlexRenew.

Proposed Facility

Service Area

The proposed development will be mixed-use, including residential, office, retail, and educational facilities that will total 7,675,000 square feet. The sewer flow from this development will not include any hazardous disposals. The sewer will only serve the proposed mixed-use development.

Project Phasing

The proposed 7,675,000 square-foot development will be developed in two phases. The first phase will include the same mix of uses but will only provide for 1,905,500 square feet. The first phase of development will still create the need for the new pump station.

The pump station will accommodate both initial Phase 1 flow as well as build-out flow from the completed development and will be designed to the satisfaction of all stakeholders.

Facility Layout

The North Potomac Yard Pump Station will be a self-cleaning type wet well and dry well configuration with an above-grade operation building. The pump station will be designed in accordance with AlexRenew Pump Station and Force Main Design Guidelines and Hydraulic Institute (HI) standards. The gravity sewer will enter the pump station at a below-grade screen room, where the wastewater will flow into an influent channel. A sluice gate will be provided to allow isolation of the station and accumulation of wastewater upstream of the self-cleaning wet well during Phase 1 to enable efficient cleaning of the wet well. A mechanically cleaned bar screen will remove large debris from the wastewater before it flows into the wet well. A 6-foot diameter manhole will be located adjacent to the pump station to be used as a connection point for Phase 2, and to provide the additional volume required during Phase 1 to self-clean the wet well.

The dry well will include two dry well submersible pumps and infrastructure to support two additional pumps to be installed with Phase 2. The pumps will have dedicated suction pipes to draw from the wet well. The pumps will discharge to a header pipe in the dry well. The discharge header will include a

magnetic flow meter to monitor discharge from the pump station. The discharge header will continue to the new force main at the exterior wall of the dry well.

The above-grade operation building will be divided into multiple rooms. The room above the screening room will include a compactor and receptacle for screenings. It will also include HVAC services, odor control systems, an operator restroom, and exterior and interior access. A stairwell will lead down to the screening room.

The area at grade-level above the dry well will be open to the dry well below and to the adjacent area above the wet well. The area above the wet well will include a solid floor with a railing at the edge of the open dry well. The area will include an overhead bridge crane for lifting pumping equipment from the dry well and moving it to the floor above the wet well. Exterior access for equipment service will be provided through the area above the wet well. A stairwell will lead down to the dry well.

A permanently installed emergency power generator with hospital grade silencer and transfer switch will be housed in a dedicated generator room in the operation building. The generator room will include ventilation and sound attenuation, as well as exterior and interior access. A 3,000-gallon aboveground fuel storage tank will be located outside the pump station building adjacent to the generator room to provide a generator fuel supply sufficient for 96 hours of operation.

The pump station site will include an access lane for service vehicles. Building access for equipment will be via roll-up doors on the north wall. The pump station building will be designed with architectural features appropriate for the proposed development.

Technical Design

The pump station will be designed in accordance with the VDEQ requirements as well as HI Standards, AlexRenew's Pump Station and Force Main Design Guidelines, National Fire Protection Association (NFPA) 820, National Electrical Code (NEC), Uniform Statewide Building Code (USBC), Occupational Safety and Health Administration (OSHA) requirements, and any other local and national applicable codes.

Pumps and Process Piping

The dry well will include four dry well submersible centrifugal wastewater pumps with approximately 75 HP motors each. The motors will include variable frequency drives (VFDs) to adjust the rotational speed and thus the flow rate from the pumps. To accommodate initial Phase 1 flow, only two of the pumps will be installed. One pump will handle the Phase 1 peak flow, and the second pump will be backup. The VFDs will adjust motor and pump speed to accommodate the low initial flow. To accommodate build-out flow after Phase 2, the impellers will be upgraded on the first two pumps, and two additional pumps will be installed. Three pumps will be used able to convey the peak flow (firm capacity) and one pump will be used provided as a backup.

The pumps have been sized and selected using a system curve analysis wherein the pump curves are superimposed upon the system curves of the discharge piping and force main. The static head for the system curves is based on the pumps off elevation in the wet well on the suction side and the force main end elevation where it will connect to the gravity system on the discharge side (existing manhole S16 for Phase 1 and existing manhole S33 for Phase 2). Pipe friction loss is based on the Hazen-Williams formula, and minor losses for bends are based on the K-factor method. For sensitivity analysis C-Factors of 110 and 130 were used to develop the system curves.

Phase 1 design flow for the proposed pump station is 0.32 MGD average daily flow and 1.07 MGD peak flow. Build-out (Phase 1 and Phase 2) design flow is 2.29 MGD average and 7.10 MGD peak. The pump station will be designed to accommodate flow for all phases from Phase 1 through build-out. To minimize disruptions and increase flexibility for future upgrades, the selected pump model will have the option to change impeller sizes and to operate at various speeds to adjust the output of the pump station. Flygt pump model NT 3231 will meet this need. The pump can be installed with small impellers down to 340 mm for Phase 1 flow conditions, and the VFDs can turn down the speed sufficiently to meet the design point. For Phase 2 when flows increase substantially, the impellers can be increased up to a maximum of 490 mm for significantly higher output, and the VFDs can adjust pump speed to match the incoming flow. As mentioned above, space in the dry well will be provided for two additional pumps to be added for the Phase 2 build-out condition.

System curve calculations and a figure including pump and system curves are included in Appendix A. The pump cut sheet is also included in Appendix A. As the design progresses, net Positive Suction Head (NPSH) will be evaluated to ensure that the required NPSH for the pump does not exceed 85% of the available NPSH.

Suction piping will be sized for a flow velocity between 2 and 5 feet per second (fps), and discharge piping will be sized for a flow velocity between 2 and 8 fps, over the range of operating conditions. Initial flush velocity will be a minimum of 3.5 fps. These requirements will be met with 14-inch suction

pipings, 12-inch pump discharge piping, and 16-inch discharge header and force main. Process piping inside the pump station will be cement lined ductile iron pipe.

A magnetic flow meter will be included inside the pump station dry well on the discharge header before the wastewater flows into the force main. The flow meter will be used with the VFDs to regulate pump speed and flow rate.

An 8-inch bypass suction pipe and connection point will be provided from the wet well, and an 8-inch bypass discharge point will be provided to the force main. Exact locations for the bypass connections will be determined as the design progresses.

Force Main

The system curve figures for Phase 1 in the Appendix are based on a 16-inch proposed force main. The discharge location for the force main is approximately one-half mile away at an existing gravity manhole S16 near East Glebe Road with invert elevation 28.7 feet. The force main material will be cement lined ductile iron pipe.

The system curve figures for Phase 2 included in Appendix A are based on a 20-inch force main. This potential upgrade will transfer the flow from the 16-inch force main to be constructed in Phase 1 to an existing 20-inch force main, currently used to discharge flow from Four Mile Run pump station. (The new 16-inch force main will then be used to discharge flow from Four Mile Run pump station.) The force main will be extended an additional half mile to discharge to an existing gravity manhole (S33) immediately downstream of the existing Potomac Yard Pump Station south of the site near East Howell Avenue. This potential upgrade will be evaluated further as the design progresses to determine the design conditions for the pumps. The selected pump model has the flexibility to accommodate a wide range of design conditions for Phase 2 by varying the impeller size and motor size or speed.

Due to the length of the force main, AlexRenew guidelines require a permanent pig launch system in the pump station for cleaning of the force main. A hydraulic surge analysis will be completed as the design progresses to assess the potential for transient surge, and necessary surge relief equipment will be provided.

Wet Well

Wet Well Type

Per AlexRenew, the proposed pump station will include a self-cleaning trench-type wet well. The HI provides guidance for designing self-cleaning trench type wet wells. A trench type self-cleaning wet well consists of a long, narrow trough, an ogee weir ramp, and sequential pump intakes. During the self-cleaning cycle, the water level is drawn down such that a hydraulic jump forms and moves down the length of the wet well, thus stirring up solids and carrying them to the last pump. At the end of the cycle, the last pump breaks suction.

Wet Well Design

The influent gravity sewer will enter the pump station at approximate elevation -2.5 feet at the influent channel. Influent wastewater will flow through the screen channel and then enter the wet well with a smooth transition to prevent air entrainment. A PVC liner will be installed on all interior surfaces of the wet well, and fillets of at least 45 degrees will be included to minimize solids build-up.

Because the pumps will be provided with VFDs to regulate flow rate, the pumps will normally vary speed to match the influent flow rate. They will only need to cycle on and off when the influent flow rate falls below the minimum pumping rate required to maintain flushing velocity in the force main. This will occur during Phase 1. In this condition, the pumps will draw down the water in the wet well to the “pumps off” level. When the wet well again fills to the “lead pump on” level, the pump will start. The wet well will be designed with sufficient operating volume to avoid frequent pump motor starts (no more than 6 to 10 per hour), to avoid septic conditions, to provide a filling time not to exceed 30 minutes at design average or minimum flow, and to allow a pump run time of at least 5 minutes during a 30 minute period of low flow, all in accordance with AlexRenew Guidelines.

The self-cleaning cycle should be performed periodically, such as 2-3 times per week. The cycle is best performed when the incoming flow rate is about half of the pumping capacity of the last pump. This will lead to a suitable draw down time and hydraulic jump to lift solids and flush them to the last pump. The wet well must be designed for build-out flow. As a result, the incoming flow during Phase 1 will not be sufficient to perform a self-cleaning cycle. To remedy this problem, a gate will be installed at the influent pipe into the pump station. This gate can be closed to backup storage in the influent gravity pipe. The influent gravity system will be sized and designed to hold a sufficient storage volume for a self-cleaning cycle. A 6-foot diameter manhole will be included on the influent pipe close to the influent connection to the pump station to provide the necessary volume. Prior to the cleaning cycle, the gate will be closed to accumulate enough wastewater upstream of the wet well to provide the appropriate velocity. When operating the cleaning cycle, the pump station influent gate will be opened and regulated to provide the needed flow rate and velocity into the wet well. Wet well calculations are included in Appendix A.

Screening System

Bar screens will be included in the influent channels of the pump station. During a cleaning cycle in the wet well, the upstream screen channel must be aligned with the wet well channel due to flow requirements. A mechanically cleaned bar screen will be installed in this channel. A screen bypass channel will be provided, including a manual bar rack and gates for isolation. The pump station design will include provisions to replace the manual bar rack with a mechanically cleaned bar screen if needed in the future; however, the operators must always use the primary screen channel that is aligned with the wet well during a self-cleaning cycle.

The mechanical screens will rake debris from the channel up to the operating floor above where they will be compacted to remove excess water and save space and will be transferred into a collection bin. Minimum recommended bar screen clear openings will be 0.5 inches. Estimated screenings volume for 0.5-inch openings will be approximately 0.1 (average) to 0.33 (peak) cubic yards per day for Phase 1, and 0.67 (average) to 2.1 (peak) cubic yards per day for Phase 2. The screen drives will include VFDs to adjust the rotation rate according to pump station influent flow rate. Safety cages will be included around the moving parts of the screen. Gates will be operable from the below-grade Screen Room operating floor without the need to enter the channels or the wet well.

Civil and Site

The site for the pump station will be in the far northeast portion of the site, closest to the CSX rail corridor. The location will be screened from the proposed development with landscaping. Per the

FEMA flood maps, this site is located in an area of minimal flood hazard. The developed site will include access to the pump station for maintenance.

Architectural

The architecture of the pump station will be processed as a DSUP amendment to be reviewed by PYDAC in conjunction with the Group 1 DSUPs and heard by Planning Commission and City Council at their October public hearings. The concept for the pump station is to create an architectural folly that is carefully integrated into design of the surrounding park. This building will invite community engagement; which may include public art, educational components that explain the infrastructure, or viewing platforms giving access to vistas of the park and Potomac River. The pump station will fulfill its functional purpose while also being a contribution to the Potomac park-scape.

Structural

All design work will be performed in accordance with the Uniform Statewide Building Code (USBC 2015) which adopts and modifies the International Building Code (IBC 2015). Concrete design will be performed in accordance with ACI 318-14 and ACI 350-06 as appropriate. Masonry design will be performed in accordance with TMS 402-13/602-13. Structural steel design will conform to requirements provided in AISC 360-10. The structure will be designed for the following load conditions:

- Live Load Design Data:
 - Roof Live Load = 20psf
 - Floor Live Load = 125psf
 - Stairway Live Load = 100psf
- Snow Load Design Data:
 - Ground Snow Load = 25psf
 - Snow Exposure Factor = 0.9
 - Thermal Factor = 1.1
 - Snow Importance Factor = 1.1
- Wind Load Design Data:
 - Risk Category = III
 - Exposure Category = D
 - Basic Wind Speed = 115mph
 - Internal Pressure Coefficient = +/- 0.18
- Seismic Design Data:
 - Risk Category = III
 - Seismic Importance Factor = 1.25
 - Seismic Site Class = D
 - $S_s = 0.118$
 - $S_1 = 0.051$
 - $S_{DS} = 0.126$
 - $S_{D1} = 0.082$
 - Seismic Design Category = B
 - Seismic System = Ordinary Reinforced Masonry Shear Walls
 - Seismic Response Modification Factor = 2
 - Deflection Amplification Factor = 1.75

- Equivalent Lateral Force Procedure

The building will consist of three levels: Lower Level, Intermediate Level, and Grade Level. The Lower Level and Intermediate Level are located below grade and will house the dry well, wet wells, and Screen Room. The Compactor Room, Generator/Electrical Room, and Restroom will be located at Grade Level. Two stairwells will connect the three levels.

The structural system below grade will consist of reinforced concrete bearing walls. These walls will be designed to resist the loads from the level above as well as the lateral soil loads as recommended in the Geotechnical Report (to be provided in the near future). Above grade, the structural system will consist of ordinary reinforced masonry shear walls, or as coordinated with the approved architectural design. The walls will support a roof system to be coordinated with the approved architectural design.

A bridge crane system will be located above the dry well. A monorail beam system will be placed in the Compactor Room. These systems will be designed such that the heaviest equipment item does not exceed 75 percent of the system lifting capacity per AlexRenew's design guidelines. Eyehooks will also be provided on the underside of the intermediate level slab to assist with maintenance and repairs.

Odor Control

Provisions for odor control will be included in the pump station. Odor control systems will be designed to control hydrogen sulfide and odors generated from the wastewater. The odor control systems will be used in conjunction with the HVAC systems at the pump station. The proposed odor control system will be an activated carbon canister. This system will draw air from the wet well and screen room into the carbon canister to remove odors and will be ventilated to outside.

HVAC and Plumbing

Ventilation will be provided for the building and the wet well in accordance with NFPA Code 820, the VDH SCAT regulations, and Virginia Occupational Safety and Health (VOSH) requirements.

Per NFPA 820 Table 9.1.1.4, below grade or partially below grade dry wells require either: a) minimum 6 air changes per hour (ACH) to be Unclassified, or b) no ventilation or less than 6 ACH to receive Class I, Division 2 NEC classification. GF recommends declassifying the dry well. Ventilation air used for the declassification of a space requires flow detection devices to provide local and remote alarms for ventilation system failure or combustible gas detection, per NFPA 820. Since the airflow is continuous, a means to heat the air in the winter will be required. The dry well will also have electric unit heaters to maintain a minimum winter temperature of 54 deg. F (adjustable). GF recommends the supply air match the set point of the room. As an energy savings for unclassified spaces, NFPA 820 allows up to 75% recirculation of the exhaust airflow rate except when the space is occupied, or a combustible gas detector senses a lower flammable limit of 10 percent or greater.

The dry well and the wet well will be separately ventilated. Ventilation requirements per NFPA 820 for wet wells are as follows:

- Ventilation rate of less than 12 ACH: Space classified Class I, Group D, Division 1
- Ventilation rate of 12 ACH continuous: Space classified Class I, Group D, Division 2

Ventilation requirements for wet wells per 9VAC25-790-380 (Virginia Administrative Code) are as follows:

- Continuous Ventilation shall be 12 ACH
- Intermittent Ventilation shall be 30 ACH

Since the Compactor Room and Screen Room (lower level) are not physically separated, GF recommends a continuous ventilation of 12 ACH. This ventilation rate allows derating of the spaces to a space classification Class I Division 2 based on NFPA 820.

NFPA 820 allows dual ventilation rates in classified spaces when all of the following criteria are met:

1. The low ventilation rate is not less than 50 percent of that specified in Table 9.1.1.4 [12 ACH]
2. The low ventilation rate is in operation only when the supply air temperature is 10° C (50° F) or less.
3. The high ventilation rate is not less than that specified in Table 9.1.1.4. [12 ACH]
4. The high ventilation rate is in operation whenever the supply air temperature is above 10° C (50° F), whenever the ventilated space is occupied, or whenever the ventilation is activated by approved combustible gas detectors set to function at 10 percent of the lower flammable limit (LFL).
5. The ventilation differential pressurization required in 9.2.5 and 9.2.6 [-0.1 in H₂O] is maintained.

Reducing the ventilation rate when allowed will generate significant energy savings. The ventilation will be accomplished with exhaust fans, supply fans, and electric duct heaters.

HVAC Description of Systems

Dry Well: A make-up air (MAU) unit will provide heated make-up air (no more than 50 deg. F.) The MAU unit will have electric heat and return air and outside air dampers. Due to the bridge crane, the MAU will have to be mounted on grade and ducted through the wall or on the roof over the generator room. If on the roof, Ductwork will drop into the generator room and run into the dry well through the wall (below the bridge crane). Some air will be ducted down to the pump room and some will supply the upper level. Exhaust fan(s) will exhaust the dry well and can be located on the roof or in the walls. One fan should have ductwork down to the lower level. Controls will be provided to allow dual ventilation rates as described previously.

Wet Well: The exhaust ductwork will draw air from both the upper and lower level. Two exhaust fans will be provided. During odor control operation, the odor control exhaust fan will pull air through the odor control unit before discharging it. When the odor control unit is offline, the normal exhaust fan will be energized. Gravity back draft dampers will be installed on the discharge of each fan so that air cannot be pulled back through the fan that is offline. Make-up air will be provided by explosion proof inline supply fans mounted overhead in the compactor room. Each fan system will have an explosion-proof electric duct heater. These will be ducted to both the compactor room and down to the screen room.

Plumbing

The pump station will also contain a restroom facility including a utility sink with water heater. Wash down hose bibbs with vacuum breakers will be provided for personnel at the exterior of the pump station, in the dry well and in the wet well. The hose bibbs will be handwheel-operated with appropriate

backflow prevention. The floors of all rooms (dry well, equipment room) will be sloped with floor drains. The dry well and stair wells will be provided with sump pumps.

Fire Protection

Fire protection will be provided in accordance with City, state, and federal requirements. At this point, it is anticipated that fire extinguishers will be provided in appropriate locations within the pump station.

Electrical

The electrical system will consist of a 1000A, 480Y/277V electrical service entrance and a rated automatic transfer switch with isolation bypass that will have a circuit breaker serving as the utility service entrance disconnect. The transfer switch will feed a motor control center (MCC) that will serve all the electrical loads. Surge protection and power monitoring will be installed on the main MCC. Variable Frequency Drives (VFDs) will be provided for the pumps and full-voltage starters for ventilation fans. VFDs will include a circuit breaker for input power, input line reactor, integral overload protection, Hand-Off-Auto selector switch and Bypass operation mode with input and output isolation contactors. Utilization equipment, lighting, and other general electrical loads and smaller process loads will be served by 208Y/120V panelboard fed through a dry-type transformer.

Generator

A diesel operated generator will be located in the generator room to back up all electrical loads through an automatic transfer switch. Based on preliminary load calculations, a generator size of 450kW is recommended for this project. The generator will have a 3,000-gallon aboveground double-walled fuel tank located outside the building to allow the generator to run for 96 hours at full load. AlexRenew design guidelines call for the fuel tank to be installed aboveground; however, due to the proposed location of the building within a publicly accessible area, it may be advisable to install the tank underground. The generator will be provided with a permanent, 100% rated, radiator mount load bank and a hospital grade silencer. Access will be designed so that the generator can be removed through a wall opening with double doors and a vent above. Eye bolts will be provided over the generator.

Instrumentation and Control

The SCADA system will include a Pump Control Panel (PCP) with an Allen Bradley CompactLogix Programmable Logic Controller (PLC) and include redundant DC power supplies, Uninterruptable Power Supply (UPS), and a graphical Operator Interface Terminal (OIT) Allen Bradley PanelView. The PCP power will be a 1-phase 120 VAC circuit and the UPS will include sizing to accommodate 24 hours of battery backup time. The telemetry system will be coordinated with the existing hardware and software used at the AlexRenew SCADA Control Center for communication compatibility. The control circuits and status indicators will follow the requirements outlined in the design guidelines including pump runtime hour meters on the front of the PCP.

The pump controls will be an alternating lead-lag operation in accordance with the operating sequence outlined in the guidelines. Pump controls will include automatic failover; if a lead pump fails the lag pump will move to the lead position. All controls will include a manual override for pump sequence selections and alternation. Normal pump alternation would be daily or as set by the operator.

The SCADA will include a weekly generator testing interlock and monitor the transfer switch and generator status. SCADA will monitor and control all major process equipment including pumps, valves, and odor control systems.

All hazardous areas will include monitoring and alarming in accordance with NFPA 820 and the AlexRenew guidelines.

A process and instrumentation diagram (P&ID) will be provided depicting the process flow including the pumps, instruments, and all other major equipment and a control narrative describing the function for each piece of process equipment.

The PCP will monitor all station alarms including, but not limited to, the following;

- Power failure,
- Dry well sump high level,
- Wet well high level,
- Wet well low level,
- Pump failure,
- Unauthorized station entry,
- Overflow level, and
- Loss of standby reserve capacity (All pumps running).

A local override to disable a “loss of reserve capacity” alarm will be provided as a switch on front of the PCP. As required all alarms will be required to be fail-safe. All alarms will be required to be annunciated to the Advanced Water Treatment Plant (AWTP) and to designated staff during off-duty hours.

Instrumentation will include magnetic flow meters for station flow measurement and radars for wet well level measurement. Placement of the level sensors will be such that turbulence will not affect the level readings. In addition to the radar level sensor a backup float level system will be provided in the event of a level sensor failure.

Construction Phasing

The pump station is new construction on an undeveloped site, which will not require phasing provisions to maintain existing service. Pump station construction will require deep excavation; support of excavation provisions will be needed. The pump station will need to be constructed prior to the sanitary sewer in the service area. The force main can be constructed concurrently with the pump station such that it is completed before or at the same time as the pump station. Utilities such as electrical power, municipal water, and communications, will need to be in place prior to startup of the pump station. A construction duration of 18 months is anticipated, and the pump station will be completed by Spring 2023.

Appendices

A. Calculations

- Preliminary system curve calculations and chart (C=110)
- Preliminary system curve calculations and chart (C=130)
- Preliminary wet well and storage calculation
- Preliminary self-cleaning wet well model for Phase 1
- Preliminary self-cleaning wet well model for Phase 2
- Generator sizing

B. Cut Sheets

- Pumps – Flygt NT 3231
- Screens – SUEZ Climber Screen
- Compactor – SUEZ Helico Compactor
- Generator – Cummins 400 KW

C. Influent Flow Calculations and Documentation

- (To be provided later)

APPENDIX A

Calculations

1. Preliminary system curve calculations and chart (C=110)
2. Preliminary system curve calculations and chart (C=130)
3. Preliminary wet well and storage calculation
4. Preliminary self-cleaning wet well model for Phase 1
5. Preliminary self-cleaning wet well model for Phase 2
6. Generator sizing



Subject System Curve for Sewage Pumps			
Job No.	62171	Project	North Potomac Yard PS
By	BMJ	Date	3/16/2020
Checked		Date	

C-Factor = 110

Phase 1 Input Values

Low WS (start)	-3.50	Suction side (Lead Pump On)
Low WS	-7.00	Suction side (Pumps Off)
Normal High WS	29.00	Discharge side (Gravity MH INV)
Max High WS	37.00	Discharge side (Surcharge MH)
Pump CL	-8.00	For NPSH calculation
H _{s-normal}	32.50	ft static head
H _{s-max}	44.00	ft max static head
h _{s-pump}	1.00	ft pump suction static head

NPSH Constants

NPSH _A = h _p - h _{vpa} + h _s - h _{fs}	
Barometric Pressure (h _p)	33.96 feet
Vapor Pres. of Water (h _{vpa})	0.78 feet (at 68°F)
Static Head on Pump (h _{s-pump})	1.00 ft
Friction Losses in Suction (h _{fs})	(included in calc. below)

C	Material	
120	PVC	Per AlexRenew 2.7.1.B
120	HDPE	Per AlexRenew 2.7.1.B
130	Cast Iron	
110	Ductile	Per AlexRenew 2.7.1.B
130	Special	Per Request

Pump Suction Piping

C	110	Ductile
L _{s1}	25	ft
D Nominal	14	inches
D _{s1}	14.52	inches
Flow Area	1.150	ft ²
K _{ts1}	5.71	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	50%	(if pipe splits and flow is divided)
Flow %	33%	(if pipe splits and flow is divided)

Pump Discharge Piping

C	110	Ductile
L _{d1}	25	ft
D Nominal	12	inches
D _{d1}	12.46	inches
Flow Area	0.847	ft ²
K _{td1}	6.22	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	50%	(if pipe splits and flow is divided)
Flow %	33%	(if pipe splits and flow is divided)

Pump Discharge Header

C	110	Ductile
L _{d1}	38	ft
D Nominal	16	inches
D _{d1}	16.6	inches
Flow Area	1.503	ft ²
K _{td1}	5.4	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)

Force Main Spur to Road

C	110	Ductile
L _{d1}	150	ft
D Nominal	16	inches
D _{d1}	16.6	inches
Flow Area	1.503	ft ²
K _{td1}	1.8	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)

Suction Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	3	0.9	2.7
Tee, Branch	1	1.8	1.8
Tee, Run	1	0.2	0.2
Wye	0	0.5	0
Reducer	1	0.13	0.13
Gate Valve	2	0.19	0.38
Check Valve	0	2.3	0
Outlet	0	1	0
Inlet	1	0.5	0.5
K _{ts1}			5.71

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	2	0.9	1.8
Tee, Branch	1	1.8	1.8
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	1	0.13	0.13
Gate Valve	1	0.19	0.19
Check Valve	1	2.3	2.3
Outlet	0	1	0
Inlet	0	0.5	0
K _{td1}			6.22

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	2	0.9	1.8
Tee, Branch	2	1.8	3.6
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valve	0	2.3	0
Outlet	0	1	0
Inlet	0	0.5	0
K _{td1}			5.4

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	2	0.9	1.8
Tee, Branch	0	1.8	0
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valve	0	2.3	0
Outlet	0	1	0
Inlet	0	0.5	0
K _{td1}			1.8

Phase 1 Avg
Phase 1 Peak
Phase 1 2.0 fps
Phase 2 2.0 fps
Phase 2 Avg
Phase 1 3.5 fps

Phase 2 3.5 fps

Phase 2 Peak

		Pump Suction Piping					Pump Discharge Piping					Pump Discharge Header					Force Main Spur to Road				
Q _s	Q _t	Q _{s1}	h _{Ls1}	V _{s1}	V _{s1} ² /2g	h _{fs1}	Q _{d1}	h _{Ld1}	V _{d1}	V _{d1} ² /2g	h _{fsd1}	Q _{d1}	h _{Ld1}	V _{d1}	V _{d1} ² /2g	h _{fsd1}	Q _{d1}	h _{Ld1}	V _{d1}	V _{d1} ² /2g	h _{fsd1}
MGD	gpm	gpm	ft	fps		ft	gpm	ft	fps		ft	gpm	ft	fps		ft	gpm	ft	fps		ft
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
0.32	225.00	225.00	0.00	0.44	0.00	0.02	225.00	0.00	0.59	0.01	0.03	225.00	0.00	0.33	0.00	0.01	225.00	0.01	0.33	0.00	0.00
1.08	750.00	750.00	0.02	1.45	0.03	0.19	750.00	0.04	1.97	0.06	0.38	750.00	0.02	1.11	0.02	0.10	750.00	0.06	1.11	0.02	0.03
2.02	1400.00	1400.00	0.06	2.71	0.11	0.65	1400.00	0.13	3.68	0.21	1.31	1400.00	0.05	2.08	0.07	0.36	1400.00	0.20	2.08	0.07	0.12
3.02	2100.00	2100.00	0.13	4.07	0.26	1.47	2100.00	0.28	5.53	0.47	2.95	2100.00	0.11	3.11	0.15	0.81	2100.00	0.42	3.11	0.15	0.27
3.31	2300.00	2300.00	0.16	4.46	0.31	1.76	2300.00	0.34	6.05	0.57	3.54	2300.00	0.13	3.41	0.18	0.97	2300.00	0.50	3.41	0.18	0.32
3.46	2400.00	2400.00	0.17	4.65	0.34	1.92	2400.00	0.36	6.32	0.62	3.85	2400.00	0.14	3.56	0.20	1.06	2400.00	0.54	3.56	0.20	0.35
4.32	3000.00	3000.00	0.26	5.81	0.52	3.00	3000.00	0.55	7.89	0.97	6.02	3000.00	0.21	4.45	0.31	1.66	3000.00	0.82	4.45	0.31	0.55
4.03	2800.00	1400.00	0.06	2.71	0.11	0.65	1400.00	0.13	3.68	0.21	1.31	2800.00	0.18	4.15	0.27	1.44	2800.00	0.72	4.15	0.27	0.48
4.75	3300.00	1650.00	0.09	3.20	0.16	0.91	1650.00	0.18	4.34	0.29	1.82	3300.00	0.25	4.89	0.37	2.01	3300.00	0.97	4.89	0.37	0.67
5.33	3700.00	1850.00	0.11	3.58	0.20	1.14	1850.00	0.22	4.87	0.37	2.29	3700.00	0.30	5.49	0.47	2.52	3700.00	1.20	5.49	0.47	0.84
6.48	4500.00	2250.00	0.15	4.36	0.30	1.69	2250.00	0.32	5.92	0.54	3.39	4500.00	0.44	6.67	0.69	3.73	4500.00	1.73	6.67	0.69	1.24
6.05	4200.00	1400.00	0.06	2.71	0.11	0.65	1400.00	0.13	3.68	0.21	1.31	4200.00	0.39	6.23	0.60	3.25	4200.00	1.52	6.23	0.60	1.08
6.48	4500.00	1500.00	0.07	2.91	0.13	0.75	1500.00	0.15	3.95	0.24	1.50	4500.00	0.44	6.67	0.69	3.73	4500.00	1.73	6.67	0.69	1.24
6.77	4700.00	1566.67	0.08	3.04	0.14	0.82	1566.67	0.17	4.12	0.26	1.64	4700.00	0.47	6.97	0.75	4.07	4700.00	1.87	6.97	0.75	1.36
7.09	4925.00	1641.67	0.09	3.18	0.16	0.90	1641.67	0.18	4.32	0.29	1.80	4925.00	0.52	7.30	0.83	4.47	4925.00	2.04	7.30	0.83	1.49
7.78	5400.00	1800.00	0.10	3.49	0.19	1.08	1800.00	0.21	4.74	0.35	2.17	5400.00	0.61	8.01	1.00	5.37	5400.00	2.42	8.01	1.00	1.79

Velocity 3.5 fps at beginning of each cycle, maintain 2 fps after flush. (AlexRenew 2.7.3.K)

Velocity 2-5 fps for suction. (AlexRenew 2.7.4.C)

Velocity 2-8 fps for discharge. (AlexRenew 2.7.4.D)

C-Factor = 110

Force Main Phase 1

C	110	Ductile
L _{d1}	2660	ft
D Nominal	16	inches
D _{d1}	16.6	inches
Flow Area	1.503	ft ²
K _{td1}	4.06	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	3	0.42	1.26
90 Bend	2	0.9	1.8
Tee, Branc	0	1.8	0
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valv	0	2.3	0
Outlet	1	1	1
Inlet	0	0.5	0
K_{td1}			4.06

Phase 2 Input Values

Low WS (start)	-3.50	Suction side (Lead Pump On)
Low WS	-7.00	Suction side (Pumps Off)
Normal High WS	43.00	Discharge side (Force Main High Point)
Max High WS	43.00	Discharge side (Force Main High Point)
Pump CL	-8.00	For NPSH calculation
H _{s-normal}	46.50	ft static head
H _{s-max}	50.00	ft max static head
h _{s-pump}	1.00	ft pump suction static head

Force Main Phase 2

C	110	Ductile
L _{d1}	5850	ft
D Nominal	20	inches
D _{d1}	20.76	inches
Flow Area	2.351	ft ²
K _{td1}	4.48	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)


Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	4	0.42	1.68
90 Bend	2	0.9	1.8
Tee, Branc	0	1.8	0
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valv	0	2.3	0
Outlet	1	1	1
Inlet	0	0.5	0
K_{td1}			4.48

Force Main Phase 1										Normal High WS		Max High WS		Force Main Phase 2										Normal High WS		Max High WS		NPSH _a
Q _{d1} gpm	h _{Ld1} ft	V _{d1} fps	V _{d1} ² /2g	h _{ind1} ft	H _s ft	TDH ft	H _s ft	TDH ft		Q _{d1} gpm	h _{Ld1} ft	V _{d1} fps	V _{d1} ² /2g	h _{ind1} ft	H _s ft	TDH ft	H _s ft	TDH ft										
+	0.00	0.00	0.00	0.00	0.00	32.50	32.50	44.00	44.00	or +	0.00	0.00	0.00	0.00	0.00	46.50	46.50	50.00	50.00		34.17							
+	225.00	0.12	0.33	0.00	0.01	32.50	32.71	44.00	44.21	or +	225.00	0.09	0.21	0.00	0.00	46.50	46.67	50.00	50.17		34.15							
+	750.00	1.11	1.11	0.02	0.08	32.50	34.53	44.00	46.03	or +	750.00	0.82	0.71	0.01	0.04	46.50	48.20	50.00	51.70		33.97							
+	1400.00	3.53	2.08	0.07	0.27	32.50	39.19	44.00	50.69	or +	1400.00	2.61	1.33	0.03	0.12	46.50	52.13	50.00	55.63		33.46							
+	2100.00	7.48	3.11	0.15	0.61	32.50	47.04	44.00	58.54	or +	2100.00	5.53	1.99	0.06	0.28	46.50	58.76	50.00	62.26		32.57							
+	2300.00	8.85	3.41	0.18	0.73	32.50	49.80	44.00	61.30	or +	2300.00	6.55	2.18	0.07	0.33	46.50	61.10	50.00	64.60		32.25							
+	2400.00	9.57	3.56	0.20	0.80	32.50	51.27	44.00	62.77	or +	2400.00	7.08	2.27	0.08	0.36	46.50	62.34	50.00	65.84		32.08							
+	3000.00	14.46	4.45	0.31	1.25	32.50	61.27	44.00	72.77	or +	3000.00	10.70	2.84	0.13	0.56	46.50	70.83	50.00	74.33		30.92							
+	2800.00	12.73	4.15	0.27	1.09	32.50	51.30	44.00	62.80	or +	2800.00	9.42	2.65	0.11	0.49	46.50	61.40	50.00	64.90		33.46							
+	3300.00	17.25	4.89	0.37	1.51	32.50	58.15	44.00	69.65	or +	3300.00	12.77	3.13	0.15	0.68	46.50	66.84	50.00	70.34		33.18							
+	3700.00	21.32	5.49	0.47	1.90	32.50	64.34	44.00	75.84	or +	3700.00	15.78	3.51	0.19	0.86	46.50	71.76	50.00	75.26		32.93							
+	4500.00	30.62	6.67	0.69	2.81	32.50	78.61	44.00	90.11	or +	4500.00	22.66	4.27	0.28	1.27	46.50	83.12	50.00	86.62		32.34							
+	4200.00	26.95	6.23	0.60	2.44	32.50	70.30	44.00	81.80	or +	4200.00	19.95	3.98	0.25	1.10	46.50	75.95	50.00	79.45		33.46							
+	4500.00	30.62	6.67	0.69	2.81	32.50	75.55	44.00	87.05	or +	4500.00	22.66	4.27	0.28	1.27	46.50	80.05	50.00	83.55		33.35							
+	4700.00	33.19	6.97	0.75	3.06	32.50	79.22	44.00	90.72	or +	4700.00	24.56	4.46	0.31	1.38	46.50	82.92	50.00	86.42		33.28							
+	4925.00	36.18	7.30	0.83	3.36	32.50	83.53	44.00	95.03	or +	4925.00	26.78	4.67	0.34	1.52	46.50	86.28	50.00	89.78		33.19							
+	5400.00	42.90	8.01	1.00	4.04	32.50	93.20	44.00	104.70	or +	5400.00	31.75	5.12	0.41	1.82	46.50	93.83	50.00	97.33		32.99							

System and Pump Curves Phase 1 (16") and Phase 2 (20")

C-Factor = 110



- | | | | |
|--|--|---|---|
| — Phase 1 FM | — Phase 2 FM | — Pump - 340 mm - 40 Hz | — Pump - 340 mm - 60 Hz |
| — Pump - 375 mm - 40 Hz | — Pump - 375 mm - 60 Hz | — 2 Pumps - 375 mm - 60 Hz | — 3 Pumps - 375 mm - 60 Hz |



Subject System Curve for Sewage Pumps			
Job No.	62171	Project	North Potomac Yard PS
By	BMJ	Date	3/16/2020
Checked		Date	

C-Factor = 130

Phase 1 Input Values

Low WS (start)	-3.50	Suction side (Lead Pump On)
Low WS	-7.00	Suction side (Pumps Off)
Normal High WS	29.00	Discharge side (Gravity MH INV)
Max High WS	37.00	Discharge side (Surcharge MH)
Pump CL	-8.00	For NPSH calculation
H _{s-normal}	32.50	ft static head
H _{s-max}	44.00	ft max static head
h _{s-pump}	1.00	ft pump suction static head

NPSH Constants

NPSH _A = h _p - h _{vpa} + h _s - h _{fs}		
Barometric Pressure (h _p)	33.96	feet
Vapor Pres. of Water (h _{vpa})	0.78	feet (at 68°F)
Static Head on Pump (h _{s-pump})	1.00	ft
Friction Losses in Suction (h _{fs})	(included in calc. below)	

C	Material	
120	PVC	Per AlexRenew 2.7.1.B
120	HDPE	Per AlexRenew 2.7.1.B
130	Cast Iron	
110	Ductile	Per AlexRenew 2.7.1.B
130	Special	Per Request

Pump Suction Piping

C	130	Special
L _{s1}	25	ft
D Nominal	14	inches
D _{s1}	14.52	inches
Flow Area	1.150	ft ²
K _{s1}	5.71	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	50%	(if pipe splits and flow is divided)
Flow %	33%	(if pipe splits and flow is divided)

Pump Discharge Piping

C	130	Special
L _{d1}	25	ft
D Nominal	12	inches
D _{d1}	12.46	inches
Flow Area	0.847	ft ²
K _{d1}	6.22	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	50%	(if pipe splits and flow is divided)
Flow %	33%	(if pipe splits and flow is divided)

Pump Discharge Header

C	130	Special
L _{d1}	38	ft
D Nominal	16	inches
D _{d1}	16.6	inches
Flow Area	1.503	ft ²
K _{d1}	5.4	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)

Force Main Spur to Road

C	130	Special
L _{d1}	150	ft
D Nominal	16	inches
D _{d1}	16.6	inches
Flow Area	1.503	ft ²
K _{d1}	1.8	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)

Suction Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	3	0.9	2.7
Tee, Branch	1	1.8	1.8
Tee, Run	1	0.2	0.2
Wye	0	0.5	0
Reducer	1	0.13	0.13
Gate Valve	2	0.19	0.38
Check Valve	0	2.3	0
Outlet	0	1	0
Inlet	1	0.5	0.5
K _{ts1}			5.71

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	2	0.9	1.8
Tee, Branch	1	1.8	1.8
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	1	0.13	0.13
Gate Valve	1	0.19	0.19
Check Valve	1	2.3	2.3
Outlet	0	1	0
Inlet	0	0.5	0
K _{dd1}			6.22

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	2	0.9	1.8
Tee, Branch	2	1.8	3.6
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valve	0	2.3	0
Outlet	0	1	0
Inlet	0	0.5	0
K _{dd1}			5.4

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	0	0.42	0
90 Bend	2	0.9	1.8
Tee, Branch	0	1.8	0
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valve	0	2.3	0
Outlet	0	1	0
Inlet	0	0.5	0
K _{dd1}			1.8

Phase 1 Avg
Phase 1 Peak
Phase 1 2.0 fps
Phase 2 2.0 fps
Phase 2 Avg
Phase 1 3.5 fps

Phase 2 3.5 fps

Phase 2 Peak

		Pump Suction Piping					Pump Discharge Piping					Pump Discharge Header					Force Main Spur to Road				
Q _s	Q _t	Q _{s1}	h _{Ls1}	V _{s1}	V _{s1} ² /2g	h _{fs1}	Q _{d1}	h _{Ld1}	V _{d1}	V _{d1} ² /2g	h _{fsd1}	Q _{d1}	h _{Ld1}	V _{d1}	V _{d1} ² /2g	h _{fsd1}	Q _{d1}	h _{Ld1}	V _{d1}	V _{d1} ² /2g	h _{fsd1}
MGD	gpm	gpm	ft	fps		ft	gpm	ft	fps		ft	gpm	ft	fps		ft	gpm	ft	fps		ft
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
0.32	225.00	225.00	0.00	0.44	0.00	0.02	225.00	0.00	0.59	0.01	0.03	225.00	0.00	0.33	0.00	0.01	225.00	0.00	0.33	0.00	0.00
1.08	750.00	750.00	0.01	1.45	0.03	0.19	750.00	0.03	1.97	0.06	0.38	750.00	0.01	1.11	0.02	0.10	750.00	0.05	1.11	0.02	0.03
2.02	1400.00	1400.00	0.05	2.71	0.11	0.65	1400.00	0.10	3.68	0.21	1.31	1400.00	0.04	2.08	0.07	0.36	1400.00	0.15	2.08	0.07	0.12
3.02	2100.00	2100.00	0.10	4.07	0.26	1.47	2100.00	0.21	5.53	0.47	2.95	2100.00	0.08	3.11	0.15	0.81	2100.00	0.31	3.11	0.15	0.27
3.31	2300.00	2300.00	0.12	4.46	0.31	1.76	2300.00	0.25	6.05	0.57	3.54	2300.00	0.09	3.41	0.18	0.97	2300.00	0.37	3.41	0.18	0.32
3.46	2400.00	2400.00	0.13	4.65	0.34	1.92	2400.00	0.27	6.32	0.62	3.85	2400.00	0.10	3.56	0.20	1.06	2400.00	0.40	3.56	0.20	0.35
4.32	3000.00	3000.00	0.19	5.81	0.52	3.00	3000.00	0.40	7.89	0.97	6.02	3000.00	0.15	4.45	0.31	1.66	3000.00	0.60	4.45	0.31	0.55
4.03	2800.00	1400.00	0.05	2.71	0.11	0.65	1400.00	0.10	3.68	0.21	1.31	2800.00	0.13	4.15	0.27	1.44	2800.00	0.53	4.15	0.27	0.48
4.75	3300.00	1650.00	0.06	3.20	0.16	0.91	1650.00	0.13	4.34	0.29	1.82	3300.00	0.18	4.89	0.37	2.01	3300.00	0.71	4.89	0.37	0.67
5.33	3700.00	1850.00	0.08	3.58	0.20	1.14	1850.00	0.16	4.87	0.37	2.29	3700.00	0.22	5.49	0.47	2.52	3700.00	0.88	5.49	0.47	0.84
6.48	4500.00	2250.00	0.11	4.36	0.30	1.69	2250.00	0.24	5.92	0.54	3.39	4500.00	0.32	6.67	0.69	3.73	4500.00	1.27	6.67	0.69	1.24
6.05	4200.00	1400.00	0.05	2.71	0.11	0.65	1400.00	0.10	3.68	0.21	1.31	4200.00	0.28	6.23	0.60	3.25	4200.00	1.12	6.23	0.60	1.08
6.48	4500.00	1500.00	0.05	2.91	0.13	0.75	1500.00	0.11	3.95	0.24	1.50	4500.00	0.32	6.67	0.69	3.73	4500.00	1.27	6.67	0.69	1.24
6.77	4700.00	1566.67	0.06	3.04	0.14	0.82	1566.67	0.12	4.12	0.26	1.64	4700.00	0.35	6.97	0.75	4.07	4700.00	1.37	6.97	0.75	1.36
7.09	4925.00	1641.67	0.06	3.18	0.16	0.90	1641.67	0.13	4.32	0.29	1.80	4925.00	0.38	7.30	0.83	4.47	4925.00	1.50	7.30	0.83	1.49
7.78	5400.00	1800.00	0.07	3.49	0.19	1.08	1800.00	0.16	4.74	0.35	2.17	5400.00	0.45	8.01	1.00	5.37	5400.00	1.78	8.01	1.00	1.79

Velocity 3.5 fps at beginning of each cycle, maintain 2 fps after flush. (AlexRenew 2.7.3.K)

Velocity 2-5 fps for suction. (AlexRenew 2.7.4.C)

Velocity 2-8 fps for discharge. (AlexRenew 2.7.4.D)

C-Factor = 130

Force Main Phase 1

C	130	Special
L _{d1}	2660	ft
D Nominal	16	inches
D _{d1}	16.6	inches
Flow Area	1.503	ft ²
K _{sd1}	4.06	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)

Discharge Minor Losses

Fitting	Number	K factor	Total K
45 Bend	3	0.42	1.26
90 Bend	2	0.9	1.8
Tee, Branch	0	1.8	0
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valve	0	2.3	0
Outlet	1	1	1
Inlet	0	0.5	0
K_{tot}			4.06

Phase 2 Input Values

Low WS (start)	-3.50	Suction side (Lead Pump On)
Low WS	-7.00	Suction side (Pumps Off)
Normal High WS	43.00	Discharge side (Force Main High Point)
Max High WS	43.00	Discharge side (Force Main High Point)
Pump CL	-8.00	For NPSH calculation
H _{s-normal}	46.50	ft static head
H _{s-max}	50.00	ft max static head
H _{s-pump}	1.00	ft pump suction static head

Force Main Phase 2

C	130	Special
L _{d1}	5850	ft
D Nominal	20	inches
D _{d1}	20.76	inches
Flow Area	2.351	ft ²
K _{d1}	4.48	
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)
Flow %	100%	(if pipe splits and flow is divided)


Discharge Minor Losses

<u>Fitting</u>	<u>Number</u>	<u>K factor</u>	<u>Total K</u>
45 Bend	4	0.42	1.68
90 Bend	2	0.9	1.8
Tee, Branch	0	1.8	0
Tee, Run	0	0.2	0
Wye	0	0.5	0
Reducer	0	0.13	0
Gate Valve	0	0.19	0
Check Valve	0	2.3	0
Outlet	1	1	1
Inlet	0	0.5	0
K_{tot}			4.48

		Force Main Phase 1				Normal High WS		Max High WS				Force Main Phase 2					Normal High WS		Max High WS			
		Q _{d1} gpm	h _{Ld1} ft	V _{d1} fps	V _{d1} ² /2g	h _{ind1} ft	H _s ft	TDH ft	H _s ft			TDH ft	Q _{d1} gpm	h _{Ld1} ft	V _{d1} fps	V _{d1} ² /2g	h _{ind1} ft	H _s ft	TDH ft	H _s ft		
+		0.00	0.00	0.00	0.00	0.00	32.50	32.50	44.00	44.00	or +	0.00	0.00	0.00	0.00	0.00	46.50	46.50	50.00	50.00	34.17	
+		225.00	0.09	0.33	0.00	0.01	32.50	32.67	44.00	44.17	or +	225.00	0.07	0.21	0.00	0.00	46.50	46.64	50.00	50.14	34.16	
+		750.00	0.82	1.11	0.02	0.08	32.50	34.20	44.00	45.70	or +	750.00	0.60	0.71	0.01	0.04	46.50	47.95	50.00	51.45	33.97	
+		1400.00	2.59	2.08	0.07	0.27	32.50	38.14	44.00	49.64	or +	1400.00	1.92	1.33	0.03	0.12	46.50	51.31	50.00	54.81	33.47	
+		2100.00	5.49	3.11	0.15	0.61	32.50	44.80	44.00	56.30	or +	2100.00	4.06	1.99	0.06	0.28	46.50	57.03	50.00	60.53	32.61	
+		2300.00	6.49	3.41	0.18	0.73	32.50	47.15	44.00	58.65	or +	2300.00	4.81	2.18	0.07	0.33	46.50	59.06	50.00	62.56	32.30	
+		2400.00	7.03	3.56	0.20	0.80	32.50	48.40	44.00	59.90	or +	2400.00	5.20	2.27	0.08	0.36	46.50	60.14	50.00	63.64	32.13	
+		3000.00	10.62	4.45	0.31	1.25	32.50	56.94	44.00	68.44	or +	3000.00	7.86	2.84	0.13	0.56	46.50	67.49	50.00	70.99	30.99	
+		2800.00	9.35	4.15	0.27	1.09	32.50	47.63	44.00	59.13	or +	2800.00	6.92	2.65	0.11	0.49	46.50	58.60	50.00	62.10	33.47	
+		3300.00	12.66	4.89	0.37	1.51	32.50	53.17	44.00	64.67	or +	3300.00	9.37	3.13	0.15	0.68	46.50	63.05	50.00	66.55	33.20	
+		3700.00	15.65	5.49	0.47	1.90	32.50	58.19	44.00	69.69	or +	3700.00	11.58	3.51	0.19	0.86	46.50	67.08	50.00	70.58	32.96	
+		4500.00	22.48	6.67	0.69	2.81	32.50	69.77	44.00	81.27	or +	4500.00	16.64	4.27	0.28	1.27	46.50	76.39	50.00	79.89	32.38	
+		4200.00	19.79	6.23	0.60	2.44	32.50	62.57	44.00	74.07	or +	4200.00	14.64	3.98	0.25	1.10	46.50	70.09	50.00	73.59	33.47	
+		4500.00	22.48	6.67	0.69	2.81	32.50	66.77	44.00	78.27	or +	4500.00	16.64	4.27	0.28	1.27	46.50	73.39	50.00	76.89	33.37	
+		4700.00	24.36	6.97	0.75	3.06	32.50	69.71	44.00	81.21	or +	4700.00	18.03	4.46	0.31	1.38	46.50	75.70	50.00	79.20	33.30	
+		4925.00	26.56	7.30	0.83	3.36	32.50	73.16	44.00	84.66	or +	4925.00	19.66	4.67	0.34	1.52	46.50	78.41	50.00	81.91	33.21	
+		5400.00	31.50	8.01	1.00	4.04	32.50	80.91	44.00	92.41	or +	5400.00	23.31	5.12	0.41	1.82	46.50	84.50	50.00	88.00	33.02	

System and Pump Curves
Phase 1 (16") and Phase 2 (20")

C-Factor = 130






Subject	Wetwell Calculations		
Job No.	62171	Project	North Potomac Yard PS
By	BMJ	Date	3/16/2020
Checked		Date	

Influent Flow Rate Calculations

	Value	Units	Comments
Phase 2 Average Flow	2,894,960	GPD	from CCL 2020-02-06
Low Flow Reduction	35%		
Low Flow Reduction	1,013,236		
	1.88	MGD	
Jack Taylor, Average	+	0.20	
North Oakville, Average	+	0.21	
Phase 2 Average Flow	2.29	MGD	
Phase 2 Average Flow	1,591	gpm	
Peaking Factor	2.5		<u>AlexRenew Guidelines, 2.5.B:</u> 2.5 peak factor minimum
Phase 2 Peak Flow	6,224,164	GPD	
	6.22	MGD	
Jack Taylor, Peak	+	0.43	
North Oakville, Peak	+	0.45	
Phase 2 Peak Flow Rating	7.10	MGD	
Phase 2 Peak Flow Rating	4,933	gpm	
Phase I Average Flow	498,260	GPD	from CCL 2020-02-06
Low Flow Reduction	35%		
Low Flow Reduction	174,391		
Phase I Average Flow	0.32	MGD	
Phase I Average Flow	225	gpm	
Peaking Factor	2.5		<u>AlexRenew Guidelines, 2.5.B:</u> 2.5 peak factor minimum
Phase I Peak Flow	1,071,259	GPD	
Phase I Peak Flow Rating	1.07	MGD	
Phase I Peak Flow Rating	744	gpm	


Pump and Wet Well Calculations

Pumping Rate at Peak, 3 Pumps	4925	gpm	Peak Flow for Phase 2 (Build-Out)
Pumping Rate, 1 Pump at Max	2400	gpm	Max Flow per Pump (Phase 2)
Pumping Rate, 1 Pump at Min	1400	gpm	Minimum flow for 2 fps velocity in force main
Theoretical Pump Cycles Per Hour	6	cyc/hr	Max 10 per hour (6 conservative) generally accepted depth = (15 * Pump Rate) / (Cycles per Hour * Wet Well Area) [derived from formulas below]
Theoretical Operating Volume (1 Pump at Min)	468	cft	
Wet Well Operating Volume	3500	gallons	
Minimum Pump Runtime at Average, Phase 1	5	min.	<u>AlexRenew Guidelines, 2.6.1.E:</u> one pump run continuously at least 5 minutes at minimum flow Assume Phase 1 Average
Influent Flow Rate	225	gpm	
Theoretical Operating Volume (1 Pump at Min)	785	cft	
Wet Well Operating Volume	5875	gallons	
Design Operating Volume Required	785	cft	Maximum of cycle volume vs. runtime volume
	5875	gallons	
Wet Well Minimum Depth	4.00	ft	Minimum submergence for suction bell From CAD Graphic From CAD Graphic
Approximate Length	34.00	ft	
Approximate Width	3.50	ft	
Wet Well Volume at Minimum Depth	476	cft	Volume at min depth + Operating volume required
+	785	cft	
Wet Well Volume Required at Pump On Level	1261	cft	



Select Wet Well Pump On Level (from bottom)	7.50	ft
Lower Section, Approx. Length	34.25	ft
Lower Section, Approx. Width	3.50	ft
Lower Section, Approx. Depth	4.50	ft
Lower Section Volume	539	cft
Middle Section, Approx. Length	37.83	ft
Middle Section, Approx. Width	6.50	ft
Middle Section, Approx. Depth	3.00	ft
Middle Section Volume	738	cft
Upper Section, Approx. Length	41.33	ft
Upper Section, Approx. Width	9.50	ft
Upper Section, Approx. Depth	0.00	ft
Upper Section Volume	0	cft
Total Volume	1277	cft

Iterate until achieve needed volume in following calc
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
From CAD Graphic
Yes Make sure matches/exceeds required volume



Normal Operating Depth	3.50	ft	Difference between Pump On and Minimum Depth
-------------------------------	-------------	-----------	--

Pump Cycle Checks

Minimum Pump Cycle	16.79	min	Shortest Pump Cycle = 4 * Volume / Pumping Rate
Maximum Pump Cycles per Hour	3.57	cyc/hr	Max 10 per hour (6 conservative) generally accepted
Min. Pump Runtime per Cycle (Phase I Avg)	5.00	min.	AlexRenew Guidelines, 2.6.1.E: one pump run continuously at least 5 minutes at minimum flow
Maximum Fill Time (Phase 1 Average)	26.12	min.	AlexRenew Guidelines, 2.6.1.C: fill time not to exceed 30 minutes at average and initial flows
Maximum Fill Time (Phase 2 Average)	3.69	min.	AlexRenew Guidelines, 2.6.1.C: fill time not to exceed 30 minutes at average and initial flows

Alternate Scenario - Pump Runtime at Startup

Minimum Pump Runtime at Low Flow, Phase 1	5	min.	AlexRenew Guidelines, 2.6.1.E: one pump run continuously at least 5 minutes at minimum flow
Influent Flow Rate	112	gpm	Assume HALF of Phase 1 Average
Theoretical Operating Volume (1 Pump at Min)	861	cft	
Wet Well Volume at Minimum Depth	476	cft	
Wet Well Volume Required at Pump On Level	1337	cft	Volume at min depth + Operating volume required

Select Wet Well Pump On Level (from bottom)	7.75	ft	Iterate until achieve needed volume in following calc
Total Volume	1375	cft	Make sure matches/exceeds required volume
Normal Operating Depth	3.75	ft	Difference between Pump On and Minimum Depth

Conclusion: Wet well can accommodate startup flow by raising "Pump On" level by 0.25 feet

Alternate Scenario - Pump Runtime at Minimal/Intermittent Flow

Minimum Pump Runtime at Low Flow, Phase 1	5	min.	AlexRenew Guidelines, 2.6.1.E: one pump run continuously at least 5 minutes at minimum flow
Influent Flow Rate	0	gpm	Assume minimal/intermittent flow
Theoretical Operating Volume (1 Pump at Min)	936	cft	
Wet Well Volume at Minimum Depth	476	cft	
Wet Well Volume Required at Pump On Level	1412	cft	Volume at min depth + Operating volume required

Select Wet Well Pump On Level (from bottom)	8.00	ft	Iterate until achieve needed volume in following calc
Total Volume	1474	cft	Make sure matches/exceeds required volume
Normal Operating Depth	4.00	ft	Difference between Pump On and Minimum Depth

Conclusion: Wet well can accommodate minimal/intermittent flow by raising "Pump On" level by 0.5 feet

Operating Elevations

Top of Wet Well	26.50	ft	from CCL dwg 2019-11-15
Grade Elevation	26.00	ft	from CCL dwg 2019-11-15
Lowest Influent Pipe Invert	-2.50	ft	-2.5 from CCL dwg 2020-02-19
Influent Channel Low Point	-4.00	ft	Approximate based on Old Potomac Yard
High Water Alarm	-1.50	ft	1 ft above lag pump on
Lag Pump On	-2.50	ft	1 ft above lead pump on
Lead Pump On	-3.50	ft	based on operating depth
Pumps Off	-7.00	ft	based on minimum depth
Low Water Alarm	-8.00	ft	1 ft below pumps off
Inside Bottom of Wet Well	-11.00	ft	From Wet Well Geometry Calc

Total Interior Depth of Wet Well	37.50	ft	Placeholder
Total Interior Depth from Grade	37.00	ft	Placeholder

Cleaning Cycle (Phase 2)

Pumping Rate (max of last pump)	2400	gpm
Cleaning Influent Rate (entering trench)	1200	gpm
Net Dewatering Rate	1200	gpm
Volume to be Dewatered	9436	gallons
Cleaning Cycle Duration (time to dewater)	7.86	minutes
Pump Station Influent Rate Available (ADF)	2300	gpm
Net Cleaning Flow Rate Shortage	0	gpm
Required Storage Volume	0	gallons

Typically about half of last pump capacity, if possible

Start with water above top of ramp
Typically 1 to 4 minutes
Phase 2 Average

Cleaning Cycle (Phase 1)

Pumping Rate (max of last pump)	2400	gpm
Cleaning Influent Rate (entering trench)	1000	gpm
Net Dewatering Rate	1400	gpm
Volume to be Dewatered	9436	gallons
Cleaning Cycle Duration (time to dewater)	6.74	minutes
Pump Station Influent Rate Available (ADF)	225	gpm
Net Cleaning Flow Rate Shortage	775	gpm
Required Storage Volume	5224	gallons
Required Storage Volume	698	cft

Typically about half of last pump capacity, if possible

Start with water above top of ramp
Typically 1 to 4 minutes
HALF of Phase 1 Average

Additional Volume Needed to Perform Cleaning Cycle
Additional Volume Needed to Perform Cleaning Cycle

Cleaning Cycle (Start-up)

Pumping Rate (max of last pump)	2400	gpm
Cleaning Influent Rate (entering trench)	1000	gpm
Net Dewatering Rate	1400	gpm
Volume to be Dewatered	9436	gallons
Cleaning Cycle Duration (time to dewater)	6.74	minutes
Pump Station Influent Rate Available (startup)	0	gpm
Net Cleaning Flow Rate Shortage	1000	gpm
Required Storage Volume	6740	gallons
Required Storage Volume	901	cft

Typically about half of last pump capacity, if possible

Start with water above top of ramp
Typically 1 to 4 minutes
Assume minimal/intermittent influent flow

Additional Volume Needed to Perform Cleaning Cycle
Additional Volume Needed to Perform Cleaning Cycle

Storage Volume in Collection System

Goal Phase 1 Avg: 698 cft
Goal Phase 1 Startup: 901 cft

OPTION 2

WS Elev. = **14.18** (Invert of Manhole S2, assume pipe full, but no surcharge behind S2)

Based on profile and data from CCL rec'd 3/3/2020

	Desc.	Dia. (in)	Dia. (ft)	L or H (ft)	Area (sqft)	V (cft)
Pipe	PS-S1	21	1.75	119.07	2.41	286.4
Manhole	S1	48	4.00	12.03	12.57	151.2
Pipe	S1-S2	10	0.83	159.91	0.55	87.2
Manhole	S2	48	4.00	0.00	12.57	0.0

Total: 524.8 cft

This is NOT enough volume.

Additional Structure for Storage Volume

Add structure for storage immediately upstream of pump station influent

Goal Phase 1 Avg: 698 cft
Goal Phase 1 Startup: 901 cft

PROPOSED

WS Elev. = **15.00** (Invert of Manhole S2, assume pipe full, but no surcharge behind S2)


Assume invert at approx. -1.5

	Desc.	Dia. (in)	Dia. (ft)	L or H (ft)	Area (sqft)	V (cft)
Storage	S0	72	6.00	16.50	28.27	466.5
Pipe	PS-S1	21	1.75	119.07	2.41	286.4
Manhole	S1	48	4.00	12.85	12.57	161.5
Pipe	S1-S2	10	0.83	159.91	0.55	87.2
Manhole	S2	48	4.00	0.82	12.57	10.3

Total: 1011.9 cft

This IS enough volume.

Conclusion: Provide 6 ft diameter structure for storage.




Author...	Details...	Assumptions...	Web Address...	The Spreadsheet...
Version 2.0 Posted on web January 3, 2003.				
Date: 3/16/2020	Project Title: North Potomac Yard Pump Station			
Client: CCL	Location: Alexandria, VA			
Job No.: 62171	Calculation by: BMJ			
Remarks: For Phase 1 at 1000 gpm influent				

Program developed by Dr. Joel Cahoon, Montana State University. Access: <http://www.coe.montana.edu/ce/joelc/wetwell/>

Section A - B	Section B - C	Uniform Flow Depth in the Circular Inlet Channel
b = 3.50 ft	b = 3.50 ft	Flow Rate = 2.23 cfs
b _f = 2.17 ft	b _f = 2.17 ft	Slope = 0.0100 ft/ft
b _s = 1.33 ft	z _f = 1.00	Diameter = 2.50 ft
z _f = 1.00	y _f = 0.67 ft	Manning's n = 0.013
z _s = 1.00	n _{concrete} = 0.011	Flow Depth = 0.40 ft
y _f = 0.67 ft	Ramp Height (ft) = 7.00	Flow Area = 0.50 ft ²
y _s = 0.67 ft	Upper Radius (ft) = 3.50	Wetted Perimeter = 2.05 ft
n _{splitter} = 0.009	Lower Radius (ft) = 2.25	Hydraulic Radius = 0.24 ft
n _{concrete} = 0.011	Length 1 (ft) = 21.50	Velocity = 4.46 ft/sec
	Length 2 (ft) = 4.50	r.h.s. = 0.0000 cfs

Run	Distance from Control x, (ft)	Elevation Head z, (ft)	Vertical Flow Depth y _v , (ft)	Normal Flow Depth y, (ft)	Water Surface Elevation y, (ft)	Mean Velocity V, (ft/sec)	Froude Number F	Energy E, (ft)	Sequent Depth y ₂ , (ft)
Node									
1	0.00	-4.00	0.40	0.40	-3.60	3.45	1.18	-3.39	
2	0.68	-4.07	0.34	0.34	-3.72	4.37	1.59	-3.40	
3	1.34	-4.27	0.30	0.27	-3.97	5.83	2.32	-3.40	
4	1.94	-4.59	0.28	0.23	-4.31	7.39	3.15	-3.42	
5	2.47	-5.03	0.28	0.20	-4.74	8.97	4.06	-3.45	
6	3.80	-6.35	0.22	0.16	-6.13	12.20	6.10	-3.59	
7	5.13	-7.68	0.20	0.14	-7.49	14.29	7.54	-3.94	
8	6.46	-9.01	0.18	0.13	-8.83	15.83	8.65	-4.45	
9	7.79	-10.34	0.17	0.12	-10.17	16.99	9.52	-5.10	
10	8.23	-10.62	0.17	0.12	-10.45	17.24	9.71	-5.23	
11	8.65	-10.83	0.14	0.12	-10.68	17.25	9.71	-5.42	
12	9.04	-10.96	0.13	0.12	-10.83	17.17	9.65	-5.58	
13	9.38	-11.00	0.12	0.12	-10.88	17.01	9.53	-5.71	1.07
14	16.55	-11.00	0.15	0.15	-10.85	13.35	6.88	-7.67	0.95
15	23.72	-11.00	0.17	0.17	-10.83	10.90	5.25	-8.71	0.86
16	32.01	-11.00	0.11	0.11	-10.89	8.76	4.74	-9.52	0.64
17	33.13	-11.00	0.12	0.12	-10.88	8.44	4.49	-9.61	0.63
18	34.26	-11.00	0.12	0.12	-10.88	7.99	4.14	-9.74	0.61
19	35.38	-11.00	0.13	0.13	-10.87	7.73	3.95	-9.81	0.60




Author...	Details...	Assumptions...	Web Address...	The Spreadsheet...
Version 2.0 Posted on web January 3, 2003.				
Date: 3/16/2020	Project Title: North Potomac Yard Pump Station			
Client: CCL	Location: Alexandria, VA			
Job No.: 62171	Calculation by: BMJ			
Remarks: For Phase 2 at 1200 gpm influent.				

Program developed by Dr. Joel Cahoon, Montana State University. Access: <http://www.coe.montana.edu/ce/joelc/wetwell/>

Section A - B	Section B - C	Uniform Flow Depth in the Circular Inlet Channel
b = 3.50 ft	b = 3.50 ft	Flow Rate = 2.67 cfs
b _f = 2.17 ft	b _f = 2.17 ft	Slope = 0.0100 ft/ft
b _s = 1.33 ft	z _f = 1.00	Diameter = 2.50 ft
z _f = 1.00	y _f = 0.67 ft	Manning's n = 0.013
z _s = 1.00	n _{concrete} = 0.011	Flow Depth = 0.43 ft
y _f = 0.67 ft	Ramp Height (ft) = 7.00	Flow Area = 0.57 ft ²
y _s = 0.67 ft	Upper Radius (ft) = 3.50	Wetted Perimeter = 2.14 ft
n _{splitter} = 0.009	Lower Radius (ft) = 2.25	Hydraulic Radius = 0.26 ft
n _{concrete} = 0.011	Length 1 (ft) = 21.50	Velocity = 4.71 ft/sec
	Length 2 (ft) = 4.50	r.h.s. = 0.0000 cfs

Run	Distance from Control x, (ft)	Elevation Head z, (ft)	Vertical Flow Depth y _v , (ft)	Normal Flow Depth y, (ft)	Water Surface Elevation y, (ft)	Mean Velocity V, (ft/sec)	Froude Number F	Energy E, (ft)	Sequent Depth y ₂ , (ft)
Node									
1	0.00	-4.00	0.43	0.43	-3.57	3.63	1.19	-3.33	
2	0.68	-4.07	0.38	0.37	-3.69	4.52	1.58	-3.34	
3	1.34	-4.27	0.33	0.31	-3.93	5.97	2.26	-3.35	
4	1.94	-4.59	0.31	0.26	-4.28	7.52	3.05	-3.36	
5	2.47	-5.03	0.32	0.23	-4.70	9.11	3.91	-3.38	
6	3.80	-6.35	0.26	0.18	-6.10	12.33	5.83	-3.51	
7	5.13	-7.68	0.23	0.16	-7.46	14.49	7.22	-3.82	
8	6.46	-9.01	0.21	0.15	-8.80	16.10	8.32	-4.28	
9	7.79	-10.34	0.20	0.14	-10.15	17.35	9.19	-4.87	
10	8.23	-10.62	0.19	0.14	-10.43	17.62	9.38	-4.98	
11	8.65	-10.83	0.16	0.14	-10.66	17.65	9.40	-5.15	
12	9.04	-10.96	0.15	0.14	-10.81	17.59	9.36	-5.30	
13	9.38	-11.00	0.14	0.14	-10.86	17.45	9.26	-5.43	1.17
14	16.55	-11.00	0.16	0.16	-10.84	14.08	6.95	-7.30	1.05
15	23.72	-11.00	0.19	0.19	-10.81	11.71	5.45	-8.36	0.97
16	32.01	-11.00	0.12	0.12	-10.88	9.61	4.98	-9.23	0.73
17	33.13	-11.00	0.13	0.13	-10.87	9.29	4.75	-9.33	0.72
18	34.26	-11.00	0.13	0.13	-10.87	8.86	4.43	-9.47	0.70
19	35.38	-11.00	0.13	0.13	-10.87	8.60	4.24	-9.55	0.69





Recommended Generator Report - 450DFEJ*

Project - North Potomac PS

Comments -

Project Requirements

Frequency, Hz	: 60.0	Generators Running in Parallel	: 1
Duty	: Standby	Site Altitude, ft(m)	: 361(110)
Voltage	: 277/480, Series Wye	Site Temperature, °C	: 25
Phase	: 3	Max. Altr Temp Rise, °C	: 150
Fuel	: Diesel	Project Voltage Distortion Limit, %	: 10
Emissions	: EPA, stationary emergency application		

Calculated Individual Generator Set Load Running and Peak Requirements

Running kW	: 376.5	Max. Step kW	: 342.0 In Step 1	Cumulative Step kW	: 342.0
Running kVA	: 439.0	Max. Step kVA	: 489.4 In Step 1	Cumulative Step kVA	: 489.4
Running PF	: 0.86	Peak kW	: None	Cumulative Peak kW	: None
Running NLL kVA	: 223.3	Peak kVA	: None	Cumulative Peak kVA	: None
Alternator kW	: 573.07			Pct Rated Capacity	: 83.6

Generator Set Configuration

Alternator	: HC5C	Engine	: QSX15-G9 Nonroad 2
BCode	: B424	Fuel	: Diesel
Excitation	: PMG	Displacement, cu in. (Litre)	: 912.0(14.9)
Voltage Range	: LimR 480	Cylinders	: 6
Number of Leads	: 12	Altitude Knee, ft(m)	: 7215(2199)
Reconnectable	: Yes	Altitude Slope, % per 1000ft(304.8m)	: 6
Full Single Phase Output	: No	Temperature Knee, °F(°C)	: 104(40)
Increased Motor Starting	: No	Temperature Slope, % per 10°F(5.56°C)	: 6
Extended Stack	: No	Emissions	: EPA Tier 2
		Cooling Package	: high ambient

Set Performance

Load Requirements

Running At	: 83.6% Rated Capacity		
Max. Step Voltage Dip, %	: 19	Max. Allowed Step Voltage Dip	: 20 In Step 1
Max. Step Frequency Dip, %	: 6	Max. Allowed Step Frequency Dip	: 10 In Step 1
Peak Voltage Dip, %	:	Peak Voltage Dip Limit %	: 20.0
Peak Frequency Dip, %	:	Peak Frequency Dip Limit %	: 10
Site Rated Standby kW/kVA	: 450 / 563	Running kW	: 376.5
		Running kVA	: 439.0
Site Rated Max. SkW	: 513	Effective Step kW	: 314.9
Max. SkVA	: 1749	Effective Step kVA	: 489.4
Temp Rise at Full Load, °C	: 150	Percent Non-Linear Load	: 54.0
Voltage Distortion	: 8.1	Voltage Distortion Limit	: 10
Site Rated Max Step kW Limit	:	Max Step kW	:

*Note: Higher temperature rise at full rated load.

*Note: All generator set power derates are based on open generator sets.



Loads Summary Report

Project - North Potomac PS

Comments -

Project Requirements

Frequency, Hz	: 60.0	Generators Running in Parallel	: 1
Duty	: Standby	Site Altitude, ft(m)	: 361(110)
Voltage	: 277/480, Series Wye	Site Temperature, °C	: 25
Phase	: 3	Max. Altr Temp Rise, °C	: 150
Fuel	: Diesel	Project Voltage Distortion Limit, %	: 10
Emissions	: EPA, stationary emergency application		

Loads Summary List

***Note: Detailed Loads and Step Report available below**

Step No.	Load Name	Quantity	Running		Starting		Peak		Dip Limits, %		VTHD% Limit
			kW	kVA	kW	kVA	kW	kVA	Vdip	Fdip	
Step01	Sewage Pump	3	62.17	69.08	6.22	6.91	None	None	20.0	10.0	10.0
Step01	Screen and Compactor	1	4.44	5.22	22.88	37.5	None	None	20.0	10.0	0.0
Step01	Exhaust Fans-VFD	2	2.49	2.77	2.49	2.77	None	None	20.0	10.0	10.0
Step01	Exhaust Fans - FVNR	2	1.89	2.39	13.3	19.0	None	None	20.0	10.0	0.0
Step01	Monorail Hoist	1	4.44	5.22	22.88	37.5	None	None	20.0	10.0	0.0
Step01	Lighting	1	10.0	10.53	10.0	10.53	None	None	20.0	10.0	10.0
Step01	Receptacles	1	5.0	5.56	5.0	5.56	None	None	20.0	10.0	0.0
Step01	Odor Control Blower	1	8.67	9.97	35.51	67.0	None	None	20.0	10.0	0.0
Step01	Unit Heater	1	40.0	50.0	40.0	50.0	None	None	20.0	10.0	0.0
Step01	Electric Water heater	1	20.0	25.0	20.0	25.0	None	None	20.0	10.0	0.0
Step01	Bridge Crane	1	8.67	9.97	35.51	67.0	None	None	20.0	10.0	0.0
Step01	Miscellaneous	1	80.0	100.0	100.0	125.0	None	None	20.0	10.0	0.0
Step Summary			376.0	439.0	342.0	489.0	None	None	20.0	10.0	10.0
Project Summary			Running		Max Starting		Cumulative Step		Cumulative Peak		Project VTHD% Limit
			kW	kVA	kW	kVA	kW	kVA	kW	kVA	
			376.5	439.0	342.0	489.4	342.0	489.4	0.0	0.0	

***Note: Detailed Loads and Step Report available below**



Loads and Steps Detail Report

Project - North Potomac PS

Comments -

Project Requirements

Frequency, Hz	: 60.0	Generators Running in Parallel	: 1
Duty	: Standby	Site Altitude, ft(m)	: 361(110)
Voltage	: 277/480, Series Wye	Site Temperature, °C	: 25
Phase	: 3	Max. Altr Temp Rise, °C	: 150
Fuel	: Diesel	Project Voltage Distortion Limit, %	: 10
Emissions	: EPA, stationary emergency application		

Calculated Individual Generator Set Load Running and Peak Requirements

Running kW	: 376.5	Max. Step kW	: 342.0 In Step 1	Cumulative Step kW	: 342.0
Running kVA	: 439.0	Max. Step kVA	: 489.4 In Step 1	Cumulative Step kVA	: 489.4
Running PF	: 0.86	Peak kW	: None	Cumulative Peak kW	: None
Running NLL kVA	: 223.3	Peak kVA	: None	Cumulative Peak kVA	: None
Alternator kW	: 573.07				

Step1

Calculated Individual Generator Set Step Load Requirements

Running kW	: 376.0	Starting kW	: 342.0	Cumulative Step kW	: 342.0
Running kVA	: 439.0	Starting kVA	: 489.0	Cumulative Step kVA	: 489.0
Running Amps	: 529.0	Starting Non-linear kVA	: 37.0		
Running Non-linear kVA	: 223.0				
Alternator kW	: 573.07				
Voltage Distortion Limit for step	: 10				

Sewage Pump	Three Phase	Quantity	: 3 In this Step
-------------	-------------	----------	------------------

Category	: Motor
----------	---------

Running kW	: 62.17	Starting kW	: 6.22	Peak kW	: None
Running kVA	: 69.08	Starting kVA	: 6.91	Peak kVA	: None
Running PF	: 0.9	Starting PF	: 0.9	Cyclic	: No
Running Amps	: 83.19	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Running NLL kVA	: 69.08				
Starting NLL kVA	: 6.91			Voltage	: 480
Alternator kW	: 124.34				

Shaft Hp	: 75.0	Type	: Variable Frequency Drive
Shaft kW	: 55.95	Ramp Details	: Slow
Rectifier Type	: 6 pulse	THDI %	: 26
Efficiency (%)	: 0.9	THDV %	: 10

Load Factor : 100.0

Screen and Compactor Three Phase Quantity : 1 In this Step

Category : Motor

Running kW	: 4.44	Starting kW	: 22.88	Peak kW	: None
Running kVA	: 5.22	Starting kVA	: 37.5	Peak kVA	: None
Running PF	: 0.85	Starting PF	: 0.61	Cyclic	: No
Running Amps	: 6.29	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Alternator kW	: 4.44			Voltage	: 480
Shaft Hp	: 5.0	Method		: Across the line	
Shaft kW	: 3.73	Low Inertia		: No	
Efficiency (%)	: 0.84	LRkVA Factor		: 7.5	
Design	: Standard NEMA Design B,C or D	LRkVA Code		: J	
Load Factor	: 100.0				

Exhaust Fans-VFD Three Phase Quantity : 2 In this Step

Category : Motor

Running kW	: 2.49	Starting kW	: 2.49	Peak kW	: None
Running kVA	: 2.77	Starting kVA	: 2.77	Peak kVA	: None
Running PF	: 0.9	Starting PF	: 0.9	Cyclic	: No
Running Amps	: 3.34	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Running NLL kVA	: 2.77				
Starting NLL kVA	: 2.77			Voltage	: 480
Alternator kW	: 4.98				
Shaft Hp	: 3.0	Type		: Variable Frequency Drive	
Shaft kW	: 2.24	Ramp Details		: None	
Rectifier Type	: 6 pulse	THDI %		: 26	
Efficiency (%)	: 0.9	THDV %		: 10	
Load Factor	: 100.0				

Exhaust Fans - FVNR Three Phase Quantity : 2 In this Step

Category : Motor

Running kW	: 1.89	Starting kW	: 13.3	Peak kW	: None
Running kVA	: 2.39	Starting kVA	: 19.0	Peak kVA	: None
Running PF	: 0.79	Starting PF	: 0.7	Cyclic	: No
Running Amps	: 2.88	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Alternator kW	: 1.89			Voltage	: 480
Shaft Hp	: 2.0	Method		: Across the line	
Shaft kW	: 1.49	Low Inertia		: No	
Efficiency (%)	: 0.79	LRkVA Factor		: 9.5	
Design	: Standard NEMA Design B,C or D	LRkVA Code		: L	
Load Factor	: 100.0				

Monorail Hoist Three Phase Quantity : 1 In this Step

Category : Motor

Running kW	: 4.44	Starting kW	: 22.88	Peak kW	: None
Running kVA	: 5.22	Starting kVA	: 37.5	Peak kVA	: None

Running PF	: 0.85	Starting PF	: 0.61	Cyclic	: No
Running Amps	: 6.29	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Alternator kW	: 4.44			Voltage	: 480
Shaft Hp	: 5.0	Method	: Across the line		
Shaft kW	: 3.73	Low Inertia	: No		
Efficiency (%)	: 0.84	LRkVA Factor	: 7.5		
Design	: Standard NEMA Design B,C or D	LRkVA Code	: J		
Load Factor	: 100.0				
<hr/>					
Lighting		Three Phase	Quantity	: 1 In this Step	
Category	: Light - LED				
<hr/>					
Running kW	: 10.0	Starting kW	: 10.0	Peak kW	: None
Running kVA	: 10.53	Starting kVA	: 10.53	Peak kVA	: None
Running PF	: 0.95	Starting PF	: 0.95	Cyclic	: No
Running Amps	: 12.68	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Running NLL kVA	: 10.53				
Starting NLL kVA	: 10.53			Voltage	: 480
Alternator kW	: 15.09				
<hr/>					
Receptacles		Three Phase	Quantity	: 1 In this Step	
Category	: General Receptacle				
<hr/>					
Running kW	: 5.0	Starting kW	: 5.0	Peak kW	: None
Running kVA	: 5.56	Starting kVA	: 5.56	Peak kVA	: None
Running PF	: 0.9	Starting PF	: 0.9	Cyclic	: No
Running Amps	: 6.69	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Alternator kW	: 5.0			Voltage	: 480
<hr/>					
Odor Control Blower		Three Phase	Quantity	: 1 In this Step	
Category	: Motor				
<hr/>					
Running kW	: 8.67	Starting kW	: 35.51	Peak kW	: None
Running kVA	: 9.97	Starting kVA	: 67.0	Peak kVA	: None
Running PF	: 0.87	Starting PF	: 0.53	Cyclic	: No
Running Amps	: 12.01	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0
Alternator kW	: 8.67			Voltage	: 480
Shaft Hp	: 10.0	Method	: Across the line		
Shaft kW	: 7.46	Low Inertia	: No		
Efficiency (%)	: 0.86	LRkVA Factor	: 6.7		
Design	: Standard NEMA Design B,C or D	LRkVA Code	: H		
Load Factor	: 100.0				
<hr/>					
Unit Heater		Three Phase	Quantity	: 1 In this Step	
Category	: User Defined				
<hr/>					
Running kW	: 40.0	Starting kW	: 40.0	Peak kW	: None
Running kVA	: 50.0	Starting kVA	: 50.0	Peak kVA	: None
Running PF	: 0.8	Starting PF	: 0.8	Cyclic	: No
Running Amps	: 60.21	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip	: 10.0

Alternator kW	: 40.0		Voltage	: 480
<hr/>				
Electric Water heater		Three Phase	Quantity	: 1 In this Step
Category	: User Defined			
<hr/>				
Running kW	: 20.0	Starting kW	: 20.0	Peak kW : None
Running kVA	: 25.0	Starting kVA	: 25.0	Peak kVA : None
Running PF	: 0.8	Starting PF	: 0.8	Cyclic : No
Running Amps	: 30.11	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip : 10.0
Alternator kW	: 20.0		Voltage	: 480
<hr/>				
Bridge Crane		Three Phase	Quantity	: 1 In this Step
Category	: Motor			
<hr/>				
Running kW	: 8.67	Starting kW	: 35.51	Peak kW : None
Running kVA	: 9.97	Starting kVA	: 67.0	Peak kVA : None
Running PF	: 0.87	Starting PF	: 0.53	Cyclic : No
Running Amps	: 12.01	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip : 10.0
Alternator kW	: 8.67		Voltage	: 480
Shaft Hp	: 10.0	Method	: Across the line	
Shaft kW	: 7.46	Low Inertia	: No	
Efficiency (%)	: 0.86	LRkVA Factor	: 6.7	
Design	: Standard NEMA Design B,C or D	LRkVA Code	: H	
Load Factor	: 100.0			
<hr/>				
Miscellaneous		Three Phase	Quantity	: 1 In this Step
Category	: User Defined			
<hr/>				
Running kW	: 80.0	Starting kW	: 100.0	Peak kW : None
Running kVA	: 100.0	Starting kVA	: 125.0	Peak kVA : None
Running PF	: 0.8	Starting PF	: 0.8	Cyclic : No
Running Amps	: 120.42	Max. % Voltage Dip	: 20.0	Max. % Frequency Dip : 10.0
Alternator kW	: 80.0		Voltage	: 480



Steps and Dips Details Report

Project - North Potomac PS

Project Requirements

Frequency, Hz	: 60.0	Generators Running in Parallel	: 1
Duty	: Standby	Site Altitude, ft(m)	: 361(110)
Voltage	: 277/480, Series Wye	Site Temperature, °C	: 25
Phase	: 3	Max. Altr Temp Rise, °C	: 150
Fuel	: Diesel	Project Voltage Distortion Limit, %	: 10
Emissions	: EPA, stationary emergency application		

Calculated Individual Generator Set Load Running and Peak Requirements

Running kW	: 376.5	Max. Step kW	: 342.0 In Step 1	Cumulative Step kW	: 342.0
Running kVA	: 439.0	Max. Step kVA	: 489.4 In Step 1	Cumulative Step kVA	: 489.4
Running PF	: 0.86	Peak kW	: None	Cumulative Peak kW	: None
Running NLL kVA	: 223.3	Peak kVA	: None	Cumulative Peak kVA	: None
Alternator kW	: 573.07				

Generator Set Configuration



Model	: 450DFEJ*	Alternator	: HC5C
Engine Model	: QSX15-G9 Nonroad 2	Excitation	: PMG
Fuel	: Diesel		high ambient

Step Level Dips Summary

Step #	Voltage Dip Limit (%)	Expected Step Voltage Dip (%)	Voltage Recovery Time (s) **	Frequency Dip Limit (%)	Expected Frequency Dip (%)	Frequency recovery Time (s) **
1	20	19	3.7	10	6	2.6

Note: Please refer to the model Spec. sheet for bandwidths used to report recovery times. For products manufactured in the United Kingdom it may be assumed that recovery times are based on ISO8528-5 G2 class bandwidths. Voltage and frequency recovery times are estimates. Typically, allow five to ten seconds between application of load steps when designing your system.

**Please note that in some cases the voltage and frequency recovery time estimates are not shown in list. This is a result of "dummy" data points temporarily being used to fill data gaps in the GenSize database. Please disregard these blank results.



APPENDIX B

Cut Sheets

1. Pumps – Flygt NT 3231
2. Screens – SUEZ Climber Screen
3. Compactor – SUEZ Helico Compactor
4. Generator – Cummins 400 KW

NT 3231/665 3~ 680


Patented self cleaning semi-open channel impeller, ideal for pumping in waste water applications. Modular based design with high adaptation grade.



Technical specification



Curves according to: Water, pure [100%], 39.2 °F, 62.42 lb/ft³, 1.6891E-5 ft²/s



Configuration

Motor number N0665.000 35-45-6AA-D 140hp	Installation type T - Vertical Permanent, Dry
Impeller diameter 340 mm	Discharge diameter 7 7/8 inch

Pump information

Impeller diameter 340 mm
Discharge diameter 7 7/8 inch
Inlet diameter 250 mm
Maximum operating speed 1185 rpm
Number of blades 3

Materials

Impeller Hard-Iron™

Project
Block

0

Created by
Created on

2/25/2020

Last update

NT 3231/665 3~ 680

Technical specification



Motor - General

Motor number N0665.000 35-45-6AA-D 140hp	Phases 3~	Rated speed 1185 rpm	Rated power 140 hp
Approval No	Number of poles 6	Rated current 179 A	Stator variant 1
Frequency 60 Hz	Rated voltage 460 V	Insulation class H	Type of Duty S1

Motor - Technical

Power factor - 1/1 Load 0.79	Motor efficiency - 1/1 Load 92.5 %	Total moment of inertia 45.9 lb ft ²	Starts per hour max. 15
Power factor - 3/4 Load 0.73	Motor efficiency - 3/4 Load 93.0 %	Starting current, direct starting 1200 A	
Power factor - 1/2 Load 0.62	Motor efficiency - 1/2 Load 92.5 %	Starting current, star-delta 399 A	

Project
Block

0

Created by
Created on

2/25/2020

Last update

NT 3231/665 3~ 680

Performance curve




Duty point

Flow
2380 US g.p.m.

Head
53 ft

Curves according to: Water, pure [100%], 39.2 °F, 62.42 lb/ft³, 1.6891E-5 ft²/s



Project

Block 0

Created by


Created on 2/25/2020

Last update

Curve: ISO 9906

NT 3231/665 3~ 680

Duty Analysis



Operating characteristics

Pumps/Systems	Flow	Head	Shaft power	Flow	Head	Shaft power	Hydr.eff.	Specific energy	NPSHr
initial duty	2380 US g.p.m.	53 ft	45.7 hp	2380 US g.p.m.	53 ft	45.7 hp	69.8 %	264 kWh/US M	10.1 ft

Project

Block 0

Created by

Created on 2/25/2020


Last update

NT 3231/665 3~ 680

VFD Curve



Curves according to: Water, pure [100%], 39.2 °F, 62.42 lb/ft³, 1.6891E-5 ft²/s



Project

Block 0

Created by


Created on 2/25/2020

Last update

Curve: ISO 9906

NT 3231/665 3~ 680

VFD Analysis



Operating Characteristics

Pumps/System	Frequency	Flow	Head	Shaft power	Flow	Head	Shaft power	Hydr. eff.	Specific Energy	NPSHr
initial duty	60 Hz	2380 US g.p.m.	53 ft	45.7 hp	2380 US g.p.m.	53 ft	45.7 hp	69.8 %	264 kWh/US M	10.1 ft
initial duty	55 Hz	2170 US g.p.m.	44.3 ft	34.9 hp	2170 US g.p.m.	44.3 ft	34.9 hp	69.8 %	225 kWh/US M	8.78 ft
initial duty	50 Hz	1980 US g.p.m.	36.6 ft	26.2 hp	1980 US g.p.m.	36.6 ft	26.2 hp	69.8 %	192 kWh/US M	7.54 ft

Project

Block 0

Created by

Created on 2/25/2020

Last update

NT 3231/665 3~ 680

Dimensional Drawing







NOTE:
PUMP CAN BE ROTATED ABOUT ITS CENTERLINE
TO 4 POSITIONS RELATIVE TO THE INLET ELBOW.
INCREMENTS ARE 90°.

* DIMENSION TO INLET ELBOW FLANGE

SUCTION/OUTLET FLANGE DRILLED ACCORDING TO CUSTOMER
SPECIFICATION

FOR COOLING JACKET DRAIN



VIEW ☒ X ☐

Motor	Weight (Lbs.)		
	Pump	Stand	Inlet Elbow
35-35-XX	2650	180	235
35-45-XX	2715	180	235



Denomination
Dimensional drwg
CT, NT 3231 665/675
dia 121 dia 8"

Drawn by NK Checked by Date 090302
Scale 1:30 Reg no 5399
6218300 5

Project
Block

0

Created by
Created on

2/25/2020

Last update

NT 3231/665 3~ 680


Patented self cleaning semi-open channel impeller, ideal for pumping in waste water applications. Modular based design with high adaptation grade.



Technical specification



Curves according to: Water, pure [100%], 39.2 °F, 62.43 lb/ft³, 1.6888E-5 ft²/s



Configuration

Motor number N0665.000 35-45-6AA-D 140hp	Installation type T - Vertical Permanent, Dry
Impeller diameter 455 mm	Discharge diameter 7 7/8 inch

Pump information

Impeller diameter 455 mm
Discharge diameter 7 7/8 inch
Inlet diameter 250 mm
Maximum operating speed 1185 rpm
Number of blades 3

Materials

Impeller Hard-Iron™

Project
Block

0

Created by
Created on

2/25/2020

Last update

NT 3231/665 3~ 680

Technical specification



Motor - General

Motor number N0665.000 35-45-6AA-D 140hp	Phases 3~	Rated speed 1185 rpm	Rated power 140 hp
Approval No	Number of poles 6	Rated current 179 A	Stator variant 1
Frequency 60 Hz	Rated voltage 460 V	Insulation class H	Type of Duty S1

Motor - Technical

Power factor - 1/1 Load 0.79	Motor efficiency - 1/1 Load 92.5 %	Total moment of inertia 50.4 lb ft ²	Starts per hour max. 15
Power factor - 3/4 Load 0.73	Motor efficiency - 3/4 Load 93.0 %	Starting current, direct starting 1200 A	
Power factor - 1/2 Load 0.62	Motor efficiency - 1/2 Load 92.5 %	Starting current, star-delta 399 A	

Project
Block

0

Created by
Created on

2/25/2020

Last update

NT 3231/665 3~ 680


Performance curve



Duty point

Flow
1330 US g.p.m.

Head
150 ft



Project

Block 0

Created by

Created on 2/25/2020

Last update


Curve: ISO 9906

NT 3231/665 3~ 680

Duty Analysis



Curves according to: Water, pure [100%], 39.2 °F, 62.43 lb/ft³, 1.6888E-5 ft²/s



Operating characteristics

Pumps/Systems	Flow	Head	Shaft power	Flow	Head	Shaft power	Hydr.eff.	Specific energy	NPSHr
1 / initial ...	3380 US g.p.m.	107 ft	116 hp	3380 US g.p.m.	107 ft	116 hp	78.9 %	459 kWh/US M	20.6 ft
3 / 1	1640 US g.p.m.	144 ft	85.1 hp	4930 US g.p.m.	144 ft	255 hp	70.2 %	692 kWh/US M	7.47 ft
2 / 1	2340 US g.p.m.	129 ft	96.2 hp	4680 US g.p.m.	129 ft	192 hp	79.5 %	549 kWh/US M	9.91 ft
1 / 1	3940 US g.p.m.	91.6 ft	128 hp	3940 US g.p.m.	91.6 ft	128 hp	71.2 %	435 kWh/US M	29.4 ft

Project

Block 0

Created by

Created on 2/25/2020

Last update


Curve: ISO 9906

NT 3231/665 3~ 680

VFD Curve



Curves according to: Water, pure [100%], 39.2 °F, 62.43 lb/ft³, 1.6888E-5 ft²/s



Project

Block 0

Created by


Created on 2/25/2020

Last update

Curve: ISO 9906

NT 3231/665 3~ 680

VFD Analysis



Operating Characteristics

Pumps/Syste s	Frequency	Flow	Head	Shaft power	Flow	Head	Shaft power	Hydr.eff.	Specific Energy	NPSHr
1 / initial ...	60 Hz	3380 US g.p.m	107 ft	116 hp	3380 US g.p.m	107 ft	116 hp	78.9 %	459 kWh/US M	20.6 ft
1 / initial ...	55 Hz	3110 US g.p.m	90.8 ft	90.6 hp	3110 US g.p.m	90.8 ft	90.6 hp	78.9 %	389 kWh/US M	18.1 ft
1 / initial ...	50 Hz	2830 US g.p.m	75.1 ft	68.1 hp	2830 US g.p.m	75.1 ft	68.1 hp	78.9 %	324 kWh/US M	15.5 ft

Project


Block 0

Created by





Created on 2/25/2020

Last update

Dimensional Drawing



SUCTION/OUTLET FLANGE DRILLED ACCORDING TO CUSTOMER SPECIFICATION

VIEW

Motor	Weight (Lbs.)		
	Pump	Stand	Inlet Elbow
35-35-XX	2650	180	235
35-45-XX	2715	180	235



Denomination
Dimensional drwg
CT,NT 3231 665/675
dia 12"/ dia 8"


Drawn by NK	Checked by	Date 090302
Scale 1:30	Reg no 5399	
6218300		5

0

Created on

2/25/2020

Last update



Climber Screen[®] mechanical bar screen

wastewater treatment

Invest in the leader: Maximize screenings capture, minimize problems. Climber Screen[®] reduces costs and complications for pump stations and wastewater treatment plants by removing channel debris before it can damage downstream equipment.

The Climber Screen[®] was developed to provide a low maintenance solution to previous screening technologies, which used permanently submerged rotating parts such as sprockets and bearings. Engineered for years of severe duty service, Climber Screen[®] can tackle large obstructions with ease. The rake simply disengages from the bar rack to clear the object until it can be removed on a subsequent pass.

ready for the resource revolution




how it works


The smooth running, endless track system employs a gear-driven cleaning rake to carry screenings from the submerged bar rack to a discharge chute for removal – without the use of chains, sprockets,

cables or any underwater moving parts. An object too large for the rake to clear will activate an alarm to reverse the unit, facilitating access for manual removal.


- 1** Cogwheels move the rake arm down the pin rack upon activation.





- 2** The rake arm enters the channel upstream from the screen.



- 3** At the bottom of the pin rack, the rake engages the screen.



- 4** Cogwheels walk the rake arm up the pin rack, transporting screenings for removal.



main features

- above water operation
- no submerged moving parts
- flexible design
- heavy duty design
- wide range of opening sizes
- positive screening discharge
- machined parts

applications

- WWTP headworks: protect downstream equipment
- pumping stations: flood control
- water intake: remove large debris
- ideal for both municipal and industrial use

features

- precision engineering
- low maintenance
- easy installation
- decades of proven performance
- machined parts
- experienced product team
- hydraulic drive option
- sanitary or cso models



technical data

MECHANICAL ADVANTAGES

- positive screenings discharge – hinged wiper assembly with smooth cushion return.
- precision engineering – machine components and removal of loose tolerance components such as chains and sprockets.
- above water operation – all moving parts remain above maximum water level during operation.
- flexible design – custom manufactured units for retrofit or new designs to suit nearly any size application.
- easy to install, control and maintain – shipped in as few parts as possible, automatic control, integral brake motor to stop the unit at any level to maintain from the easiest access point.

TECHNICAL FEATURES

- flow rates 1.5 to 300 MGD
- machine widths 18" to 30'-0"
- machine depths up to 90'-0"
- bar clear openings 1/4" to 6"
- rake speed 20, 30 and 40 fpm

standard duty

model	application range		max. water level	available bar rack spacing
	channel width	flow type		
MODEL I	1' 6"-3' 0"	sanitary	8' 6" (without special construction or submergence protection)	1/4" to 6"
MODEL II	3' 1"-5' 6"	sanitary		
MODEL IIIA	5' 4"-6' 6"	sanitary		
MODEL IIIA	6' 7"-12' 0"	sanitary		

severe duty

model	application range		max. water level	available bar rack spacing
	channel width	flow type		
MODEL IIS	3' 6" - 7' 0"	combined	recommended max. not to exceed 2 times the channel width	1/4" to 6"
MODEL IIIS	7' 4" - 12' 0"	combined		
MODEL IIIBS	12' 0" - 16' 0"	combined * flood control & storm drainage		
MODEL IIVS	16' 0" - 30' 0"	combined * flood control & storm drainage		

(*) flood control maximum through velocity: 2.25 fps

general requirements

minimum approach velocity	maximum* through velocity	desired upstream channel length	minimum upstream channel length
1.5 fps	5.0 fps	4 x channel width	2 x channel width

(*) flood control maximum through velocity: 2.25 fps

A RELIABLE INVESTMENT WITH YEARS OF RETURN

- Maximizing screenings capture reduces downstream equipment loading, thus lasting longer and with fewer mechanical problems.
- The Climber Screen® consists of a smooth, vibration-free bilateral, endless pin rack system. The roller and bushing system is designed specifically for this linear track application.
- The Climber Screen® unit is engineered to last and to be virtually maintenance-free. Finely-tuned components such as the pin racks, bearing design, and close tolerance cam tracking pay for themselves in longevity and reduced maintenance costs.



Climber Screen®

mechanical bar screen



precision design and fabricating

With state-of-the-art engineering tools and a trained staff available, Infilco can offer detailed solid modeling for ease of installation into existing structures as well as complete new designs.



options



fiberglass odor enclosure



patented submersible motor enclosure



hydraulic drive system

services

Aftermarket

SUEZ in North America sells parts and components for most SUEZ brand equipment as well as parts for demineralizers, thickeners, nozzles, pressure filters, and valves. We offer reliable spare parts at competitive prices. We maintain records of previous installations to quickly identify your requirements. Many items are shipped directly from stock for quick delivery.

Rebuilds, Retrofits and Upgrades

SUEZ in North America offers cost-effective rebuilds and upgrades for SUEZ provided systems, no matter what year they were built. If you are interested in an economical alternative to installing a whole new system, contact us for a proposal.

If interested in this product, check out some of our complementary products:

- ABW® Automatic Backwash Filter
- AquaDAF® Clarifier
- Cleargreen®
- Densadeg® Clarifier/Thickener
- Ferazur®/Mangazur®
- Meteor® IFAS/MBBR
- Ultragreen™
- Climber Screen®
- Vortex®
- Cannon® Mixer
- 2PAD
- Thermylis® HTFB

contact

SUEZ
8007 Discovery Drive
Richmond, VA 23229 USA
Tel. : +1 804 756 7600
Fax : +1 804 756 7643
sales.usa@suez-na.com



Helico™ screenings washer & compactor

wastewater treatment

→ **EFFICIENCY**

- screenings are more easily transported to the landfill or incinerated

→ **COST SAVINGS**

- reduce maintenance and handling costs related to screenings

reliable screenings removal for
optimum wastewater treatment
plant performance

ready for the resource revolution



Helico™ — the natural complement to the Climber Screen® and all mechanically cleaned bar screens.

Multiple sizes of models available to suit the need of any application.

MODEL 200

8" Diameter Auger (nominal)

Auger helical flight thickness: 1/2"

Screenings Capacity:

- Nominal Minimum: 25-33 cubic ft/hr
- Nominal Max: 100 cubic ft/hr

MODEL 300

12" Diameter Auger (nominal)

Auger helical flight thickness: 5/8"


Screenings Capacity:

- Nominal Minimum: 50-75 cubic ft/hr
- Nominal Max: 150 cubic ft/hr

Dual Hopper units available for both Models 200 & 300.

Dual Hopper units are the optimal solution for plants with multiple screen units in close proximity to one another, utilizing a single efficient 2 hp motor, press-tube, auger and discharge location for multiple hopper inlets.

Screenings Wash Header attachments are available for aiding in the removal of biological matter from debris and odor reduction of dewatered screenings.



KEY FIGURE:

screenings volume reduction up to

75%

advantages

- finished moisture content of less than 55%
- 65-85% weight reduction of screenings
- volume reduction of 70-75%
- rate of feed can vary without effect on operation or performance
- robust and durable construction
- single & dual hopper configurations
- automatic startup tied to bar screen functions with option for skip cycle counter operation.
- specially patterned counter-sunk drain hole configuration reduces clogging and congestion without the need of a brush or wiper attachment
- solid shaft of hardened steel and thick auger flights provides robust and long-lasting operation
- available with either victaulic or flanged schedule 40 piping connections

contact

SUEZ
8007 Discovery Drive
Richmond, VA 23229 USA
Tel. : +1 804 756 7600
Fax : +1 804 756 7643
sales.usa@suez-na.com

042016





Diesel generator set QSX15 series engine

450 kW – 500 kW Standby



Description

Cummins® commercial generator sets are fully integrated power generation systems providing optimum performance, reliability and versatility for stationary standby and prime power applications.

Features

Cummins heavy-duty engine - Rugged 4-cycle, industrial diesel delivers reliable power, low emissions and fast response to load changes.

Alternator - Several alternator sizes offer selectable motor starting capability with low reactance 2/3 pitch windings, low waveform distortion with non-linear loads and fault clearing short-circuit capability.

Permanent Magnet Generator (PMG) - Offers enhanced motor starting and fault clearing short-circuit capability.

Control system - The PowerCommand® electronic control is standard equipment and provides total genset system integration including automatic remote starting/stopping, precise frequency and voltage regulation, alarm and status message display, AmpSentry™ protection, output metering, auto-shutdown at fault detection and NFPA 110 Level 1 compliance.

Cooling system - Standard integral set-mounted radiator system, designed and tested for rated ambient temperatures, simplifies facility design requirements for rejected heat.

Enclosures - Optional weather protective and sound attenuated enclosures are available.

Fuel tanks - Dual wall sub-base fuel tanks are also available.

NFPA - The genset accepts full rated load in a single step in accordance with NFPA 110 for Level 1 systems.

Warranty and service - Backed by a comprehensive warranty and worldwide distributor network.

	Standby rating	Prime rating	Continuous rating	Data sheets
Model	60 Hz kW (kVA)	60 Hz kW (kVA)	60 Hz kW (kVA)	60 Hz
DFEJ	450 (563)	410 (513)		D-3400
DFEK	500 (625)	455 (569)		D-3401

Generator set specifications

Governor regulation class	ISO 8528 part 1 Class G3
Voltage regulation, no load to full load	± 0.5%
Random voltage variation	± 0.5%
Frequency regulation	Isochronous
Random frequency variation	± 0.25%
EMS compatibility	IEC 61000-4-2: Level 4 Electrostatic discharge IEC 61000-4-3: Level 3 Radiated susceptibility

Engine specifications

Design	Turbocharged with air-to-air charge air-cooling
Bore	136.9 mm (5.39 in.)
Stroke	168.9 mm (6.65 in.)
Displacement	14.9 L (912.0 in ³)
Cylinder block	Cast iron with replaceable wet liners, in-line 6 cylinder
Battery capacity	1400 Amps minimum at ambient temperature 0 °C (32 °F)
Battery charging alternator	35 Amps
Starting voltage	24 volt, negative ground
Fuel system	Full authority electronic (FAE) Cummins HPI-TP
Fuel filter	
Air cleaner type	
Lube oil filter type(s)	Single spin-on combination full flow and bypass filters
Standard cooling system	40 °C (104 °F) ambient radiator

Alternator specifications

Design	Brushless, 4 pole, drip-proof revolving field
Stator	2/3 pitch
Rotor	Single bearing, flexible discs
Insulation system	Class H
Standard temperature rise	125 °C standby at 40 °C ambient
Exciter type	PMG (Permanent Magnet Generator)
Phase rotation	A (U), B (V), C (W)
Alternator cooling	Direct drive centrifugal blower fan
AC waveform total harmonic distortion (THDV)	< 5% no load to full linear load, < 3% for any single harmonic
Telephone influence factor (TIF)	< 50% per NEMA MG1-22.43
Telephone harmonic factor (THF)	< 3%

Available voltages

60 Hz Line – Neutral/Line - Line

- | | | | |
|-----------|-----------|-----------|-----------|
| • 110/190 | • 110/220 | • 115/200 | • 115/230 |
| • 120/208 | • 127/220 | • 139/240 | • 220/380 |
| • 230/400 | • 240/416 | • 255/440 | • 277/480 |
| • 347/600 | | | |

Note: Consult factory for other voltages.

Generator set options

Engine

- 208/240/480 V thermostatically controlled coolant heater for ambient above 4.5 °C (40 °F)
- 208/240/480 V thermostatically controlled coolant heater for ambient below 4.5 °C (40 °F)
- 120 V 300 W lube oil heater
- Heavy duty air cleaner with safety element

Alternator

- 80 °C rise
- 105 °C rise
- 150 °C rise
- 120/240 V 200 W anti-condensation heater

Exhaust system

- Critical grade exhaust silencer
- Exhaust packages
- Industrial grade exhaust silencer
- Residential grade exhaust silencer

Fuel system

- 1022 L (270 gal) sub-base tank
- 1136 L (300 gal) sub-base tank
- 1514 L (400 gal) sub-base tank
- 1893 L (500 gal) sub-base tank
- 2271 L (600 gal) sub-base tank
- 2498 L (660 gal) sub-base tank
- 3218 L (850 gal) sub-base tank
- 6435 L (1700 gal) sub-base tank
- 9558 L (2525 gal) sub-base tank

Cooling system

- High ambient 50 °C radiator

Control panel

- PC 3.3
- PC 3.3 with MLD
- 120/240 V 100 W control anti-condensation heater
- Ground fault indication
- Remote fault signal package
- Run relay package

Generator set

- AC entrance box
- Battery
- Battery charger
- Export box packaging
- UL 2200 Listed
- Main line circuit breaker
- Paralleling accessories
- Remote annunciator panel
- Spring isolators
- Enclosure: aluminium, steel, weather protective or sound attenuated
- 2 year standby power warranty
- 2 year prime power warranty
- 5 year basic power warranty
- 10 year major components warranty

*Note: Some options may not be available on all models - consult factory for availability.

Control system 2.3

The PowerCommand 2.3 control system - An integrated generator set control system providing voltage regulation, engine protection, generator protection, operator interface and isochronous governing (optional).

Control - Provides battery monitoring and testing features and smart-starting control system.

InPower™ - PC-based service tool available for detailed diagnostics.

PCCNet RS485 - Network interface (standard) to devices such as remote annunciator for NFPA 110 applications.

Control boards - Potted for environmental protection.

Ambient operation - Suitable for operation in ambient temperatures from -40 °C to +70 °C and altitudes to 13,000 feet (5000 meters). Prototype tested - UL, CSA and CE compliant.

AC protection

- AmpSentry protective relay
- Over current warning and shutdown
- Over and under voltage shutdown
- Over and under frequency shutdown
- Over excitation (loss of sensing) fault
- Field overload
- Overload warning
- Reverse kW shutdown
- Reverse Var shutdown
- Short circuit protection

Engine protection

- Overspeed shutdown
- Low oil pressure warning and shutdown
- High coolant temperature warning and shutdown
- Low coolant level warning or shutdown
- Low coolant temperature warning

- High, low and weak battery voltage warning
- Fail to start (overcrank) shutdown
- Fail to crank shutdown
- Redundant start disconnect
- Cranking lockout
- Sensor failure indication
- Low fuel level warning or shutdown
- Fuel-in-rupture-basin warning or shutdown

Operator/display panel

- Manual off switch
- 128 x 128 Alpha-numeric display with push button access for viewing engine and alternator data and providing setup, controls and adjustments (English or international symbols)
- LED lamps indicating genset running, not in auto, common warning, common shutdown, manual run mode and remote start
- Suitable for operation in ambient temperatures from -20 °C to +70 °C

Alternator data

- Line-to-Neutral AC volts
- Line-to-Line AC volts
- 3-phase AC current
- Frequency
- kVA, kW, power factor

Engine data

- DC voltage
- Lube oil pressure
- Coolant temperature

Control functions

- Time delay start and cool down
- Glow plug control (some models)
- Cycle cranking
- PCCNet interface
- (4) Configurable inputs
- (4) Configurable outputs
- Remote emergency stop
- Battle short mode
- Load shed
- Real time clock with exerciser
- Derate

Digital governing (optional)

- Integrated digital electronic isochronous governor
- Temperature dynamic governing

Digital voltage regulation

- Integrated digital electronic voltage regulator
- 3-phase Line-to-Line sensing
- Configurable torque matching
- Fault current regulation under single or three phase fault conditions

Other data

- Genset model data
- Start attempts, starts, running hours
- Fault history
- RS485 Modbus® interface
- Data logging and fault simulation (requires InPower service tool)
- Total kilowatt hours
- Load profile

Options

- Auxiliary output relays (2)
- 120/240 V, 100 W anti-condensation heater
- Remote annunciator with (3) configurable inputs and (4) configurable outputs
- PMG alternator excitation
- PowerCommand for Windows® remote monitoring software (direct connect)
- AC output analogue meters
- PowerCommand 2.3 and 3.3 control with AmpSentry protection

For further detail on PC 2.3 see document S-1569.

For further detail on PC 3.3 see document S-1570.

Emergency Standby Power (ESP):

Applicable for supplying power to varying electrical load for the duration of power interruption of a reliable utility source. Emergency Standby Power (ESP) is in accordance with ISO 8528. Fuel Stop power in accordance with ISO 3046, AS 2789, DIN 6271 and BS 5514.

Limited-Time running Power (LTP):


Applicable for supplying power to a constant electrical load for limited hours. Limited Time Running Power (LTP) is in accordance with ISO 8528.

Prime Power (PRP):

Applicable for supplying power to varying electrical load for unlimited hours. Prime Power (PRP) is in accordance with ISO 8528. Ten percent overload capability is available in accordance with ISO 3046, AS 2789, DIN 6271 and BS 5514.

Base Load (Continuous) Power (COP):

Applicable for supplying power continuously to a constant electrical load for unlimited hours. Continuous Power (COP) in accordance with ISO 8528, ISO 3046, AS 2789, DIN 6271 and BS 5514.



This outline drawing is for reference only. See respective model data sheet for specific model outline drawing number.





Do not use for installation design

Model	Dim 'A' mm (in.)	Dim 'B' mm (in.)	Dim 'C' mm (in.)	Set weight dry* kg (lbs)	Set weight wet* kg (lbs)
DFEJ	3864 (152.1)	1524 (60.0)	1812 (71.3)	4098 (9035)	4234 (9335)
DFEK	3864 (152.1)	1524 (60.0)	1812 (71.3)	4325 (9535)	4461 (9835)

*Weights represent a set with standard features. See outline drawings for weights of other configurations.

Codes and standards

Codes or standards compliance may not be available with all model configurations – consult factory for availability.

	<p>This generator set is designed in facilities certified to ISO 9001 and manufactured in facilities certified to ISO 9001 or ISO 9002.</p>		<p>The generator set is available listed to UL 2200, Stationary Engine Generator Assemblies for all 60 Hz low voltage models. The PowerCommand control is Listed to UL 508 - Category NITW7 for U.S. and Canadian usage. Circuit breaker assemblies are UL 489 Listed for 100% continuous operation and also UL 869A Listed Service Equipment.</p>
	<p>The Prototype Test Support (PTS) program verifies the performance integrity of the generator set design. Cummins products bearing the PTS symbol meet the prototype test requirements of NFPA 110 for Level 1 systems.</p>	<p>U.S EPA</p>	<p>Engine certified to Stationary Emergency U.S. EPA New Source Performance Standards, 40 CFR 60 subpart IIII Tier 2 exhaust emission levels. U.S. applications must be applied per this EPA regulation.</p>
	<p>All low voltage models are CSA certified to product class 4215-01.</p>	<p>International Building Code</p>	<p>The generator set package is available certified for seismic application in accordance with the following International Building Code: IBC2000, IBC2003, IBC2006, IBC2009 and IBC2012.</p>

Warning: Back feed to a utility system can cause electrocution and/or property damage. Do not connect to any building's electrical system except through an approved device or after building main switch is open.

For more information contact your local Cummins distributor or visit power.cummins.com

Our energy working for you.™



©2017 Cummins Inc. All rights reserved. Cummins is a registered trademark of Cummins Inc. PowerCommand, AmpSentry, InPower and "Our energy working for you." are trademarks of Cummins Inc. Other company, product, or service names may be trademarks or service marks of others. Specifications are subject to change without notice. S-1582 (08/17)

APPENDIX C

Influent Flow Calculations and Documentation

(To be provided later)